

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
			24 Hr	Initials	deg C	<.1	mg/L		>1.2mg/L	>7.3	PSI	PSI														
1	0735	Bm	0.66	6.8	7.5	.024	1.6	-	1.4	7.0	53	52	10	11	10	10	10	11	10	11	12	11			24.4	3588327
2	0840	Bm	0.66	7.1	8.0	.024	1.6	-	1.4	7.1	53	52	10	10	10	10	10	10	10	11	12	11			24.9	3589618
3	0915	Bm	0.64	6.9	8.0	.025	1.5	7.0	1.4	7.0	53	52	10	10	10	10	10	10	10	10	11	10			24.5	3590886
4	10:10	Mr	0.74	6.9	8.0	.025	1.7	7.4	1.3	7.0	53	52	10	10	10	10	10	10	10	10	11	10			25.8	3592385
5	10:10	Mr	0.71	6.8	8.0	.024	1.6	7.5	1.2	7.0	53	52	10	10	10	10	10	10	10	10	10	10			26.4	3593794
6	14:00	Mr	0.85	6.8	8.5	.023	1.7	7.6	1.2	7.1	53	52	10	10	9	10	10	9	10	10	10	10			24.8	3595178
7	1050	Bm	0.71	6.8	8.5	.024	1.6	7.3	1.4	7.1	53	52	9	9	9	10	9	9	9	10	10	10	X	X	26.1	3596179
8	0845	Bm	0.88	6.8	8.5	.025	1.6	7.8	1.4	7.2	53	52	9	9	9	9	9	9	9	10	10	10			24.5	3597354
9	1020	Bm	0.70	6.9	8.5	.024	1.6	7.6	1.3	7.3	53	52	9	9	9	9	9	9	9	9	10	9			25.3	3598705
10	1155	Tw	0.67	6.9	6.0	.023	1.7	7.4	1.3	7.1	52	51	10	9	9	9	9	9	9	9	9	9			26.1	3600144
11	19:00	Mr	0.83	6.8	9.0	.023	1.6	7.4	1.2	7.1	53	52	10	9	9	9	9	9	9	9	10	9			24.8	3602301
12	7:30	Mr	0.76	6.8	9.0	.023	1.5	7.5	1.2	7.2	53	52	9	9	9	9	9	9	9	10	10	9			24.8	3602823
13	1830	Mr	0.64	6.8	9.0	.023	1.4	7.5	1.2	7.2	53	52	9	9	9	9	9	9	9	9	10	9			26.2	3604633
14	1010	Bm	0.67	6.9	7.0	.023	1.6	7.7	1.4	7.4	53	52	10	9	9	9	9	9	9	9	10	9			25.7	3605396
15	0805	Bm	0.68	6.9	7.0	.023	1.6	7.7	1.4	7.3	53	52	9	9	9	9	9	9	9	9	10	9	X		25.5	3606527
16	0900	Bm	0.64	6.9	7.0	.024	1.5	7.8	1.3	7.5	53	52	9	9	9	9	9	9	9	9	10	9			26.4	3607772
17	0905	Tw	0.63	6.9	7.0	.023	1.8	7.6	1.3	7.3	52	51	9	9	9	9	9	9	9	9	9	9			26.3	3608980
18	0730	Mr	0.73	6.9	9.5	.023	1.6	7.6	1.2	7.2	53	52	10	10	9	9	9	9	9	9	10	10			25.2	3610281
19	10:00	Mr	0.82	6.9	9.5	.023	1.6	7.6	1.2	7.2	53	51	9	9	9	9	9	9	9	9	10	9			26.0	3612014
20	8:00	Mr	0.77	6.8	9.5	.024	1.7	7.6	1.2	7.2	53	52	9	9	9	9	9	9	9	9	10	9			25.7	3613142
21	0925	Bm	0.67	7.0	9.5	.023	1.6	7.8	1.4	7.3	53	52	9	9	9	9	9	9	9	9	9	9			26.1	3614699
22	1020	Bm	0.65	6.9	9.5	.025	1.5	7.6	1.4	7.4	53	52	9	9	9	9	9	9	9	9	9	9	X		26.0	3616090
23	0940	Bm	0.74	7.0	9.5	.024	1.5	7.8	1.4	7.5	53	52	9	9	9	9	9	9	9	9	9	9			26.0	3617442
24	0720	Tw	0.69	6.9	9.5	.024	1.8	7.6	1.3	7.2	52	51	10	9	9	9	9	9	9	9	9	9			26.0	3618745
25	7:45	Mr	0.73	6.9	10.0	.023	1.6	7.6	1.2	7.2	52	51	9	9	9	9	9	9	9	9	9	9			26.0	3620016
26	12:30	Mr	0.83	6.9	9.5	.025	1.7	7.6	1.2	7.2	52	51	9	9	9	9	9	9	9	9	9	9			25.1	3621703
27	10:45	Mr	0.82	6.9	9.5	.023	1.6	7.6	1.2	7.2	52	51	9	9	9	9	9	9	9	9	9	9			25.3	3622931
28	0830	Bm	0.66	6.9	7.5	.023	1.7	7.6	1.4	7.3	52	51	9	9	9	9	9	9	9	9	10	9			25.5	3624050
29	0925	Bm	0.67	6.9	9.5	.025	1.6	7.7	1.4	7.4	52	51	9	9	9	9	9	9	9	9	9	9	X	X	26.1	3625439
30	0920	Bm	0.69	6.9	7.5	.024	1.6	7.7	1.4	7.3	52	51	9	9	9	9	9	9	9	9	9	9			25.4	3626910
31	1225	Tw	0.69	6.8	9.0	.024	1.7	7.5	1.4	7.1	52	51	11	9	9	9	9	9	9	9	9	9			25.4	3628312

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

MONTH 07 YEAR 2019-2020

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F -	Clear well Level - Daily						
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	Gallons		
1	0735	Bm																5700			
2	0800	Bm																5600	RAW 7.1 DISTR-7.1		
3	0915	Bm																5600			
4	10:10	Mt																5700			
5	10:10	Mt																5700			
6	11:00	Mt																5700			
7	1050	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5800			
8	0845	Bm																5700			
9	1020	Bm																5600	RAW-6.9 DISTR-7.3		
10	1155	TW																5600			
11	19:00	Mt																5800			
12	7:50	Mt																5700			
13	18:30	Mt																5600			
14	1025	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5800			
15	0805	Bm																5700			
16	0900	Bm																5600	RAW-6.9 DISTR-7.5		
17	0905	TW																5800			
18	0750	Mt																5900			
19	10:00	Mt																5800			
20	8:00	Mt																5700			
21	9:25	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5800	RAW 7.0 DISTR 7.3		
22	1020	Bm																5700			
23	0900	Bm																5700			
24	0720	TW																6000			
25	7:45	Mt																5600			
26	12:30	Mt																5700			
27	10:45	Mt																5700			
28	0830	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5700			
29	0925	Bm																5300			
30	0920	Bm																5800	RAW 6.9 DISTR 7.3		
31	1225	TW																5600			