

MONTH 09 YEAR 2019 ~~2020~~

[illegible]

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out														
	24 Hr	Initials			deg C	<.1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi													
1	830	BM	0.69	6.9	9.5	.024	1.5	7.8	1.3	7.3	53	52	10	9	9	9	10	9	9	9	10	9		X	26.9	3672211
2	940	BM	0.75	6.9	9.5	.023	1.5	7.9	1.4	7.5	52	51	9	9	9	9	10	9	10	9	10	9			26.1	3673496
3	740	BM	0.65	6.9	9.5	.023	1.6	7.9	1.4	7.3	52	51	9	9	9	9	9	9	9	9	9	9			26.1	3674760
4	1135	TW	0.70	6.9	8.5	.024	1.8	7.5	1.4	7.1	75	73	12	10	"	"	12	"	12	"	12	"			30.1	3676392
5	14:30	AK	0.68	6.8	9.0	.024	1.6	7.5	1.2	7.2	74	73	10	10	10	10	11	10	10	10	11	10			30.3	3677970
6	13:00	AK	0.75	6.8	9.5	.025	1.6	7.8	1.2	7.2	74	73	10	10	10	10	10	10	10	10	10	10			30.3	3679682
7	8:45	AK	0.69	6.8	9.0	.023	1.5	7.8	1.3	7.2	74	73	10	10	10	10	10	10	10	10	10	10			29.1	3680738
8	825	BM	0.77	6.8	8.5	.025	1.5	7.8	1.4	7.5	75	73	10	10	10	10	10	10	10	10	11	10		X	29.7	3681893
9	900	BM	0.70	6.8	7.0	.024	1.6	8.0	1.4	7.6	75	73	10	10	10	10	10	10	10	10	10	10			28.7	3683016
10	750	BM	0.77	6.8	7.0	.024	1.5	8.0	1.4	7.5	75	73	10	10	10	10	10	10	10	10	11	10			29.4	3683967
11	0700	TW	0.70	6.9	7.5	.024	1.7	7.5	1.4	7.2	74	73	10	10	10	10	10	10	10	10	10	10			28.2	3684976
12	11:00	AK	0.72	6.8	6.5	.026	1.5	7.8	1.2	7.2	74	73	10	10	10	10	11	10	10	10	11	10			28.3	3686462
13	11:40	AK	0.75	6.8	7.0	.025	1.6	7.8	1.3	7.2	75	73	10	10	10	10	10	10	10	10	11	10			28.6	3687470
14	8:50	AK	0.81	6.8	7.0	.024	1.6	7.8	1.3	7.2	75	73	10	10	10	10	11	10	10	10	11	10			29.1	3688392
15	1035	BM	0.64	6.8	7.5	.024	1.7	8.0	1.4	7.7	75	73	10	10	10	10	10	10	10	10	11	10		X	28.3	3689547
16	835	BM	0.65	6.8	7.5	.025	1.5	7.9	1.5	7.7	75	73	10	10	10	10	10	10	10	10	11	11			28.5	3690419
17	850	BM	0.69	6.8	7.5	.024	1.6	7.5	1.4	7.4	75	72	10	10	10	10	10	10	10	10	11	11			29.8	3691457
18	1020	TW	0.88	6.9	7.5	.024	1.9	7.5	1.4	7.3	74	72	"	10	"	10	"	"	"	"	12	11			29.2	3692540
19	14:00	AK	0.77	6.8	8.0	.024	1.6	7.6	1.4	7.2	74	72	10	10	10	10	11	10	10	10	11	10			30.1	3693852
20	11:30	AK	0.68	6.8	8.0	.024	1.5	7.6	1.3	7.1	74	72	10	10	10	10	10	10	10	10	11	10			29.5	3695017
21	10:45	AK	0.67	6.8	7.5	.023	1.6	7.7	1.4	7.2	75	72	10	10	10	10	10	10	10	10	11	10			28.7	3696047
22	9:50	BM	0.57	6.8	7.5	.024	1.5	7.6	1.4	7.3	75	71	10	10	10	10	10	10	10	10	11	10		X	30.1	3697031
23	8:20	BM	0.62	6.8	8.0	.024	1.6	7.8	1.4	7.5	76	75	10	10	10	10	10	10	10	10	11	10			28.3	3698109
24	840	BM	0.67	6.8	8.0	.025	1.5	7.9	1.4	7.6	74	73	10	10	10	10	10	10	10	10	11	10			30.2	3699245
25	1150	TW	0.70	6.8	8.5	.024	1.6	7.6	1.3	7.2	72	72	10	10	10	10	10	10	10	10	10	10			28.6	3700588
26	11:07	AK	0.67	6.8	8.0	.025	1.6	7.7	1.3	7.2	73	71	9	10	10	9	10	9	9	10	10	10			28.7	3701396
27	12:20	AK	0.66	6.8	8.0	.024	1.6	7.6	1.4	7.2	75	73	9	10	10	10	10	9	9	10	10	10			30.3	3702419
28	11:30	AK	0.63	6.8	7.0	.024	1.7	7.8	1.3	7.2	75	74	10	9	10	9	10	10	10	10	10	10			29.2	3703262
29	0935	BM	0.62	6.8	6.5	.024	1.5	7.8	1.3	7.6	74	75	9	9	10	10	10	10	10	10	10	10		X	29.6	3703953
30	0800	BM	0.59	6.8	7.0	.025	1.6	7.9	1.4	7.3	74	75	10	10	10	10	10	10	10	10	10	10			28.4	3704660
31																										

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.