

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out														
		OPER	NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
	24 Hr	Initials			deg C	<.1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi													
1	0900	BW	0.56	6.8	6.5	.025	1.9	8.0	1.4	7.8	74	75	9	9	9	9	10	10	10	10	10	10			29.1	3705683
2	1015	TW	0.59	6.7	6.5	.024	1.9	7.5	1.4	7.3	73	71	10	9	9	10	10	10	10	10	9			29.4	3706582	
3	1345	MR	0.58	6.8	6.5	.025	1.9	7.7	1.2	7.2	74	75	10	10	10	10	10	10	10	10	10			27.6	3707631	
4	1225	MR	0.61	6.8	6.5	.024	1.7	7.8	1.4	7.2	74	72	10	10	10	10	10	10	10	10	10			29.0	3708607	
5	9:45	MR	0.60	6.8	6.5	.025	1.7	7.6	1.4	7.2	73	75	10	9	9	9	9	9	9	10	10			28.7	3709425	
6	9:25	BW	0.59	6.8	6.5	.025	1.7	7.7	1.5	7.6	74	75	10	10	10	10	10	10	10	10	10	X	X	29.0	3710207	
7	625	BW	0.58	6.8	6.5	.025	1.6	7.7	1.3	7.3	74	75	10	10	10	10	10	10	10	10	10			29.9	3711022	
8	940	BW	0.63	6.8	6.5	.025	1.5	7.9	1.3	7.3	73	75	9	9	9	9	10	10	10	10	10			29.9	3712047	
9	0900	TW	0.57	6.8	6.5	.024	1.8	7.7	1.3	7.2	74	70	10	10	10	10	10	10	10	10	10			28.7	3712809	
10	1300	MR	0.60	6.8	6.5	.025	1.6	7.6	1.3	7.2	72	74	10	10	10	10	10	10	10	10	10			30.2	3713966	
11	9:00	MR	0.70	6.8	7.0	.025	1.6	7.6	1.2	7.1	75	72	10	10	10	10	10	10	10	10	10			29.0	3714898	
12	14:05	MR	0.65	6.8	7.0	.025	1.7	7.5	1.4	7.1	75	72	10	10	10	10	10	11	10	10	11			29.1	3715867	
13	835	BW	0.63	6.8	6.5	.025	1.6	7.8	1.4	7.2	76	73	10	10	10	10	10	10	10	11	10	X		28.6	3716468	
14	930	BW	0.52	6.8	6.5	.025	1.6	7.7	1.4	7.1	75	69	10	10	10	10	10	10	10	10	10			28.6	3717396	
15	840	BW	0.61	6.8	6.5	.025	1.7	7.8	1.4	7.2	76	73	10	10	10	10	10	10	10	10	10			28.4	3718188	
16	0900	TW	0.54	6.8	6.0	.025	1.8	7.5	1.4	7.1	75	72	11	10	10	10	10	10	10	10	11			29.3	3718946	
17	6:10	MR	0.56	6.8	6.0	.025	1.6	7.6	1.4	7.1	75	70	10	10	10	10	10	10	10	10	10			27.1	3719783	
18	9:50	MR	0.62	6.8	6.5	.025	1.6	7.7	1.4	7.1	75	72	10	10	10	10	10	10	10	10	10			29.1	3720646	
19	10:45	MR	0.61	6.8	6.5	.025	1.6	7.6	1.3	7.2	75	72	10	10	10	10	10	10	10	10	10			28.7	3721587	
20	1040	BW	0.72	6.8	6.5	.025	1.6	7.8	1.3	7.4	75	73	11	10	11	10	11	10	10	10	11		X	29.2	3722409	
21	945	BW	0.55	6.8	6.5	.025	1.5	7.9	1.4	7.2	75	73	10	10	10	10	10	10	10	10	10			29.4	3723277	
22	950	BW	0.58	6.8	6.5	.025	1.6	8.0	1.3	7.3	75	72	11	10	10	10	10	10	10	10	10			29.8	3724022	
23	1000	BW	0.57	6.8	5.5	.025	1.6	7.9	1.4	7.4	76	73	11	11	10	10	10	11	11	11	10			28.8	3724681	
24	11:00	MR	0.84	6.8	6.0	.025	1.6	7.8	1.4	7.2	75	72	10	10	10	10	10	10	10	10	10			29.4	3725403	
25	1:40	MR	0.74	6.8	5.5	.025	1.6	7.8	1.3	7.2	75	72	10	10	10	10	10	10	10	10	10			28.7	3726129	
26	1:15	MR	0.58	6.8	5.0	.025	1.7	7.8	1.4	7.2	76	73	10	10	10	10	10	10	10	10	10			28.2	3726732	
27	1400	BW	0.56	6.8	5.5	.025	1.6	7.9	1.5	7.3	76	69	10	10	10	10	10	10	10	10	11	X	X	28.4	3727388	
28	1010	BW	0.68	6.8	5.0	.026	1.7	7.6	2.0	7.6	76	73	11	11	11	10	11	11	11	10	11			29.8	3727928	
29	0810	BW	0.74	6.8	5.5	.025	1.7	7.9	1.6	7.6	75	73	11	10	10	10	10	11	10	11	10			30.0	3728663	
30	1200	TW	0.58	6.8	5.5	.025	1.8	7.8	1.5	7.6	75	72	11	11	10	11	11	12	12	11	11			27.7	3729566	
31	10:40	MR	0.61	6.8	5.5	.025	1.7	7.8	1.6	7.4	75	69	11	10	10	10	11	11	11	10	11			29.3	3730319	

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F -	Clear well Level - Daily						
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	Gallons		
1	0910	BN																5600	RAW-6-8, DISTR 7-8		
2	1015	TW																5600			
3	11:45	AK																5600			
4	12:25	AK																5700			
5	9:45	AK																5700			
6	925	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5600			
7	625	Bm																5700			
8	940	Bm																5600	RAW-6-8 DISTR-7-3		
9	0730	TW																6000			
10	1300	AK																5800			
11	9:00	AK																5600			
12	14:05	AK																5700			
13	835	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5700			
14	930	Bm																5700			
15	840	Bm																5600	RAW-6-8 DISTR-7-2		
16	0820	TW																5600			
17	9:10	AK																5700			
18	9:50	AK																5800			
19	10:45	AK																5800			
20	1040	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5700			
21	945	Bm																5800			
22	950	Bm																5500	RAW-6-8 DISTR-7-3		
23	1000	Bm																5800			
24	1100	AL																5600			
25	140	AL																5700			
26	115	AL																5800			
27	1400	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5800			
28	1000	Bm																5500			
29	810	Bm																5600	RAW-6-8 DISTR-7-6		
30	1200	TW																5800			
31	1040	AL																5700			