

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser				
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out																		
	24 Hr	Initials			deg C	<1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi																	
1	10:30	AK	0.63	6.8	5.5	0.026	1.7	7.8	1.4	7.3	75	72	11	11	10	10	11	11	11	10	11	11			29.0	3731223				
2	13:20	AK	0.70	6.8	5.5	0.026	1.6	7.8	1.4	7.2	75	70	11	11	10	10	11	11	11	10	11	10			28.7	3732157				
3	10:00	BM	0.71	6.8	5.5	0.026	1.6	7.8	1.5	7.4	75	73	11	10	10	10	11	11	11	11	11	11	X		29.4	3732759				
4	9:55	BM	0.59	6.8	5.5	0.026	1.8	7.9	1.4	7.3	76	73	10	10	10	10	10	10	10	10	11	11			29.1	3733605				
5	10:00	BM	0.62	6.8	5.5	0.025	1.7	7.9	1.5	7.3	76	73	11	10	11	11	11	11	11	11	11	11			28.4	3734387				
6	12:00	AK	0.62	6.8	5.5	0.025	1.7	7.9	1.5	7.3	76	73	11	10	11	11	11	11	11	11	11	11			28.4	3734387				
7	14:15	AK	0.82	6.8	4.7	0.026	1.8	7.7	1.4	7.2	76	73	10	10	10	10	10	10	10	10	10	10			24.7	3736835				
8	9:50	AK	0.82	6.8	4.7	0.026	1.8	7.7	1.4	7.2	76	73	10	10	10	10	10	10	10	10	10	10			24.7	3736835				
9	10:30	AK	0.91	6.8	4.0	0.027	1.7	7.8	1.3	7.2	75	73	10	10	10	10	10	10	10	10	10	10			27.5	3738301				
10	10:10	BM	0.91	6.8	3.5	0.025	1.8	8.2	1.5	7.7	76	73	10	10	10	10	11	11	11	11	11	11	X		24.6	3739951				
11	09:00	BM	1.04	6.8	3.0	0.028	1.7	7.8	1.5	7.8	76	73	9	9	9	9	10	10	10	10	10	10			26.2	3741182				
12	09:45	BM	0.96	6.8	3.5	0.027	1.7	8.0	1.5	7.4	76	74	10	10	10	10	10	10	10	10	10	10			26.2	3742501				
13	11:45	AK	1.08	6.8	3.0	0.028	1.6	7.6	1.4	7.5	76	74	9	10	9	9	10	10	10	10	10	10			26.0	3743894				
14	11:30	AK	0.95	6.8	3.0	0.027	1.6	8.0	1.3	7.2	76	73	10	10	10	10	10	10	10	10	10	10			26.3	3745189				
15	11:40	AK	1.09	6.8	3.0	0.027	1.5	7.8	1.4	7.2	76	73	10	10	10	10	10	10	10	10	10	10			25.8	3746566				
16	11:30	AK	1.13	6.8	3.0	0.028	1.5	7.8	1.2	7.3	76	73	9	10	9	10	10	10	10	10	10	10			25.7	3748067				
17	9:15	BM	0.62	6.8	3.0	0.025	1.6	7.8	1.3	7.4	76	73	10	10	10	10	10	10	10	10	10	10	X	X	25.7	3748903				
18	7:30	BM	0.54	6.8	3.5	0.026	1.6	7.9	1.5	7.6	76	73	10	10	10	10	10	10	10	10	10	10			26.4	3750124				
19	10:25	BM	0.96	6.8	3.5	0.026	1.6	7.7	1.3	7.4	76	73	10	10	10	10	10	10	10	10	10	10			26.5	3751552				
20	11:45	AK	0.71	6.8	3.0	0.025	1.6	7.5	1.3	7.3	76	74	10	10	10	10	10	10	10	10	10	10			26.4	3755863				
21	13:40	AK	0.85	6.8	3.0	0.026	1.4	7.7	1.3	7.4	76	74	10	10	10	10	10	10	10	10	10	10			25.1	3754311				
22	11:30	AK	0.70	6.8	3.0	0.025	1.4	7.7	1.2	7.3	76	70	10	10	10	10	10	10	10	10	10	10			26.1	3755358				
23	8:10	AK	0.92	6.8	3.0	0.026	1.3	7.8	1.3	7.2	76	73	10	10	10	10	10	10	10	10	10	10			26.6	3756744				
24	10:50	BM	0.62	6.8	2.5	0.026	1.4	7.6	1.3	7.4	75	72	10	10	10	10	10	10	10	10	10	10	X		25.3	3759570				
25	08:50	BM	0.56	6.8	2.5	0.026	1.5	8.0	1.4	7.4	75	69	12	12	11	12	11	12	12	11	12	12			30.2	3761745				
26	07:50	BM	0.60	6.8	2.5	0.026	1.6	8.0	1.4	7.5	75	72	12	12	12	12	12	12	12	12	12	12			30.3	3764157				
27	11:20	AK	0.62	6.8	2.0	0.026	1.6	8.0	1.4	7.3	75	72	11	11	10	10	11	11	11	11	11	11			30.1	3767295				
28	11:40	AK	0.79	6.8	2.0	0.026	1.5	8.0	1.3	7.4	75	72	11	11	10	11	11	11	11	11	11	11			30.6	3769791				
29	10:15	AK	0.75	6.8	2.5	0.026	1.4	8.0	1.3	7.4	75	72	11	11	10	10	11	11	11	11	11	11			30.4	3771963				
30	9:10	AK	0.59	6.8	2.0	0.026	1.6	8.0	1.3	7.4	75	73	12	12	12	12	12	12	12	12	12	12			29.8	3774287				
31																														

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

MONTH 11 YEAR 2019-2020

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F	Clear water Level - Daily	Gallons					
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP			
1	10:30	AK																	5800		
2	13:20	AK																	5800		
3	10:00	BM	X		X		X		X		X		X		X		X		5800		
4	9:55	BM																	5800		
5	10:20	BM																	5900	RAW-6.8 DISTR-7.3	
6																					
7	14:15	AK																	5900		
8	9:50	AK																	5900		
9	10:30	AK																	5900		
10	10:15	BM	X		X		X		X		X		X		X		X		5800	INDIVIDUAL FILTER TEST	
11	09:00	BM																	5900		
12	09:45	BM																	5900	RAW-6.8 DISTR-7.4	
13	11:45	AK																	6000		
14	11:30	AK																	5800		
15	11:40	AK																	5800		
16	4:30	AK																	5700		
17	9:15	BM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5900		
18	7:30	BM																	5600		
19	10:25	BM																	5900	RAW-6.8 DISTR-7.4	
20	11:45	AK																	5800		
21	13:40	AK																	5700		
22	11:30	AK																	5800		
23	12:00	BM	X		X		X		X		X		X		X		X		5600		
24	08:50	BM																	5700		
25	07:50	BM																	5600	RAW-6.8 DISTR-7.5	
26	11:20	AK																	5700		
27	11:40	AK																	5600		
28	10:15	AK																	5600		
29	9:	AK																	5700		
30	9:10	AK																	5900		
31																					