

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
			24 Hr	Initials	deg C	<.1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi													
1	0850	Bm	0.80	6.8	2.0	0.026	1.5	7.8	1.3	7.5	75	72	12	12	11	11	12	12	12	11	12	12	X	X	30.3	3776706
2	0925	Bm	0.82	6.8	2.5	0.026	1.6	7.8	1.4	7.4	75	72	12	11	11	11	12	11	12	11	12	11			31.3	3779213
3	1005	Bm	0.60	6.8	2.0	0.028	1.7	7.9	1.4	7.3	75	69	12	11	11	11	12	12	12	11	11	12			30.0	3781724
4	0900	TW	0.72	6.8	2.0	0.024	1.7	7.8	1.4	7.4	75	72	12	10	10	10	11	13	12	11	12	12			31.0	3784092
5	10:10	Mx	0.63	6.8	2.0	0.026	1.7	7.7	1.3	7.2	75	70	12	11	10	10	11	11	11	11	12	11			30.6	3785424
6	19:10	Mx	0.68	6.8	2.0	0.026	1.6	7.6	1.3	7.2	75	72	12	11	11	11	12	12	12	11	12	11			30.9	3787144
7	10:15	Mx	0.72	6.8	2.0	0.026	1.6	7.6	1.4	7.2	75	72	12	11	11	12	12	12	12	11	12	12			30.1	3787764
8	0900	Bm	0.61	6.8	2.5	0.026	1.6	7.9	1.4	7.4	75	72	12	11	11	11	11	11	12	11	12	11	X		30.8	3788888
9	0910	Bm	0.61	6.8	2.5	0.026	1.6	7.8	1.4	7.4	75	72	11	11	11	11	11	11	11	11	12	11			30.3	3790060
10	0910	Bm	0.72	6.8	2.5	0.026	1.6	7.8	1.4	7.3	75	70	12	11	11	11	12	11	11	11	11	11			30.3	3791165
11	1145	TW	0.56	6.8	2.0	0.027	1.7	7.5	1.4	7.1	75	72	11	11	11	10	12	11	11	11	12	11			30.5	3792405
12	11:15	Mx	0.61	6.8	2.0	0.026	1.8	7.6	1.5	7.1	75	72	12	11	11	11	12	11	11	12	12	12			29.5	3793570
13	10:40	Mx	0.66	6.8	2.0	0.026	1.7	7.6	1.4	7.1	75	69	12	11	11	11	11	11	11	11	12	12			31.2	3794676
14	9:30	Mx	0.80	6.8	2.0	0.026	1.9	7.6	1.3	7.0	75	72	11	10	10	10	10	11	11	11	11	11			28.5	3795708
15	9:25	Bm	0.68	6.8	2.0	0.027	1.6	8.1	1.5	7.5	75	72	11	10	11	10	11	11	12	12	12	12	X	X	30.3	3796818
16	9:20	Bm	0.75	6.8	2.0	0.027	1.6	8.0	1.5	7.8	75	72	12	11	10	10	11	11	11	11	12	11			31.1	3797937
17	10:15	Bm	0.72	6.8	2.0	0.026	1.7	7.9	1.4	7.4	75	72	11	10	10	10	11	12	11	11	12	11			30.1	3799093
18	12:00	TW	0.67	6.8	2.0	0.027	1.7	7.5	1.4	7.1	75	72	13	11	11	11	12	11	11	11	11	12			30.4	3800333
19	10:30	Mx	0.66	6.8	2.0	0.029	1.8	7.6	1.4	7.2	75	72	12	11	10	10	11	11	11	11	12	11			30.1	3801384
20	11:00	Mx	0.59	6.8	2.0	0.026	1.8	7.6	1.4	7.1	75	72	12	11	11	11	11	12	12	11	12	11			30.3	3802606
21	11:45	Mx	0.70	6.8	2.0	0.026	1.7	7.6	1.4	7.1	75	72	12	10	10	11	11	11	11	11	12	11			30.5	3803867
22	0845	Bm	0.60	6.8	2.0	0.027	1.6	7.8	1.4	7.4	75	72	12	11	11	11	11	11	12	11	12	12	X		30.4	3804768
23	0805	Bm	0.62	6.8	2.0	0.026	1.7	7.8	1.4	7.4	75	72	12	11	10	10	11	11	11	11	11	12			30.0	3805935
24	0840	Bm	0.66	6.8	2.0	0.026	1.6	8.1	1.5	7.6	75	72	11	11	11	11	11	11	11	11	11	11			30.9	3807203
25	10:25	TW	0.64	6.8	2.0	0.026	1.6	7.9	1.4	7.6	75	72	13	11	11	11	13	12	12	12	12	12			30.8	3808507
26	12:30	Mx	0.68	6.8	2.0	0.026	1.7	7.7	1.5	7.2	75	72	12	11	11	11	12	12	12	12	12	12			30.0	3809985
27	11:20	Mx	0.65	6.8	2.0	0.026	1.6	7.6	1.4	7.2	75	72	12	11	11	11	11	12	11	11	12	12			30.4	3811056
28	10:00	Mx	0.70	6.8	2.0	0.026	1.5	7.6	1.4	7.1	75	72	12	11	11	11	11	11	11	11	12	12			30.3	3812157
29	0910	Bm	0.73	6.8	2.0	0.027	1.6	7.6	1.4	7.2	75	72	12	12	11	11	11	11	11	11	12	12	X	X	30.5	3813303
30	0820	Bm	0.59	6.8	2.0	0.027	1.5	7.8	1.5	7.4	75	72	12	11	11	11	11	12	12	11	12	12			31.8	3814508
31	0955	Bm	0.64	6.8	1.5	0.026	1.5	7.8	1.5	7.3	75	72	12	11	11	11	12	12	11	12	12	11			31.0	3815851

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F -	Clear well Level - Daily								
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP		Gallons	
1	0850	BM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		5700	
2	0925	BM																				5600	
3	1005	BM																				5600	
4	0905	BM																				5600	
5	10:10	BM																				5600	
6	10:10	BM																				5600	
7	10:15	BM																				5700	
8	0900	BM	X		X		X		X		X		X		X		X		X			5600	
9	0910	BM																				5900	
10	0910	BM																				5500	
11	1145	TW																				5600	
12	11:15	BM																				5700	
13	10:40	BM																				5700	
14	9:30	BM																				5600	
15	925	BM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		5700	
16	920	BM																				5600	
17	1015	BM																				5700	
18	1200	TW																				5700	
19	10:30	BM																				5700	
20	11:00	BM																				5700	
21	11:45	BM																				5800	
22	0945	BM	X		X		X		X		X		X		X		X		X			5800	
23	0805	BM																				5900	
24	0840	BM																				5600	
25	1025	TW																				5600	
26	14:30	BM																				5700	
27	11:20	BM																				5600	
28	10:00	BM																				5700	
29	0910	BM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		5900	
30	0820	BM																				5900	
31	0955	BM																				5700	

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete

Note: MIT - Pass (P) or Fail (F)

Note: CIP - X for complete