



Organic Chemicals Certified Laboratory Report Form
WQCD - Drinking Water CAS
Submit Online at <http://www.wqcdcompliance.com/login>

Revised 4/13/2015

VOC/SOC

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
Public Water System Information		Certified Laboratory Information	
PWSID#: CO0207504		Laboratory ID: CO 00063	
System Name: Meadow Mtn Water Supply		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Andrew Griffiths	Phone #: 303-747-2066	Contact Person: Customer Service	Phone: 303-659-2313
Comments:	Do Samples Need to be Composited BY THE LAB? ☐	Comments:	

PWSID#: CO0207504		Section III (Supplied or Completed by Public Water System)							
Sample Date:	8/17/20	Collector:	Andrew Griffiths	Facility ID (On Schedule):	001	Sample Pt ID (On Schedule):	001		
Section IV Volatile Organic Chemicals (Supplied or Completed by Certified Laboratory)									
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name		CAS No.	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
8/17/20	8/21/20	200817093-01C	1,1,1-Trichloroethane		71-55-6	EPA-524.2	200	0.5	BDL
8/17/20	8/21/20	200817093-01C	1,1,2-Trichloroethane		79-00-5	EPA-524.2	5	0.5	BDL
8/17/20	8/21/20	200817093-01C	1,1-Dichloroethylene		75-35-4	EPA-524.2	7	0.5	BDL
8/17/20	8/21/20	200817093-01C	1,2,4-Trichlorobenzene		120-82-1	EPA-524.2	70	0.5	BDL
8/17/20	8/21/20	200817093-01C	1,2-Dichloroethane		107-06-2	EPA-524.2	5	0.5	BDL
8/17/20	8/21/20	200817093-01C	1,2-Dichloropropane		78-87-5	EPA-524.2	5	0.5	BDL
8/17/20	8/21/20	200817093-01C	Benzene		71-43-2	EPA-524.2	5	0.5	BDL
8/17/20	8/21/20	200817093-01C	Carbon Tetrachloride		56-23-5	EPA-524.2	5	0.5	BDL
8/17/20	8/21/20	200817093-01C	Monochlorobenzene		108-90-7	EPA-524.2	100	0.5	BDL
8/17/20	8/21/20	200817093-01C	cis-1,2-Dichloroethylene		156-59-2	EPA-524.2	70	0.5	BDL
8/17/20	8/21/20	200817093-01C	Dichloromethane		75-09-2	EPA-524.2	5	0.5	BDL
8/17/20	8/21/20	200817093-01C	Ethylbenzene		100-41-4	EPA-524.2	700	0.5	BDL
8/17/20	8/21/20	200817093-01C	o-Dichlorobenzene		95-50-1	EPA-524.2	600	0.5	BDL
8/17/20	8/21/20	200817093-01C	Para-Dichlorobenzene		106-46-7	EPA-524.2	75	0.5	BDL
8/17/20	8/21/20	200817093-01C	Styrene		100-42-5	EPA-524.2	100	0.5	BDL
8/17/20	8/21/20	200817093-01C	Tetrachloroethylene		127-18-4	EPA-524.2	5	0.5	BDL
8/17/20	8/21/20	200817093-01C	Toluene		108-88-3	EPA-524.2	1000	0.5	BDL
8/17/20	8/21/20	200817093-01C	trans-1,2-Dichloroethylene		156-60-5	EPA-524.2	100	0.5	BDL
8/17/20	8/21/20	200817093-01C	Trichloroethylene		79-01-6	EPA-524.2	5	0.5	BDL
8/17/20	8/21/20	200817093-01C	Vinyl chloride		75-01-4	EPA-524.2	2	0.5	BDL
8/17/20	8/21/20	200817093-01C	Xylenes (total)		1330-20-7	EPA-524.2	10000	0.5	BDL

NT: Not Tested ug/L: Micrograms per Liter MCL: Maximum Contaminant Level BDL Below Laboratory MRL A less than sign (<) may also be used.

200817093-01 Y

1/2
8/31/20

PWSID#: CO0207504		Section V (Supplied or Completed by Public Water System)						
Sample Date:	8/17/20	Collector:	Andrew Griffiths	Facility ID (On Schedule):	001	Sample Pt ID (On Schedule):	001	
Section VI Synthetic Organic Chemicals (Supplied or Completed by Certified Laboratory)								
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name	CAS No.	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
8/17/20	8/21/20	200817093-01	Dibromochloropropane	96-12-8	EPA 504.1	0.2	0.02	BDL
8/17/20	8/22/20	200817093-01B	2,4,-D	94-75-7	EPA 515.4	70	0.1	BDL
8/17/20	8/22/20	200817093-01B	2,4,5-TP	93-72-1	EPA 515.4	50	0.2	BDL
8/17/20	8/29/20	200817093-01D	Alachlor	15972-60-8	EPA 525.2	2	0.2	BDL
8/17/20	8/20/20	200817093-01E	Aldicarb	116-06-3	EPA 531.1	N/A	0.6	BDL
8/17/20	8/20/20	200817093-01E	Aldicarb sulfone	1646-88-4	EPA 531.1	N/A	1	BDL
8/17/20	8/20/20	200817093-01E	Aldicarb sulfoxide	1646-87-3	EPA 531.1	N/A	0.7	BDL
8/17/20	8/29/20	200817093-01D	Atrazine	1912-24-9	EPA 525.2	3	0.1	BDL
8/17/20	8/29/20	200817093-01D	Benzo(a)pyrene	50-32-8	EPA 525.2	0.2	0.02	BDL
8/17/20	8/20/20	200817093-01E	Carbofuran	1563-66-2	EPA 531.1	40	0.9	BDL
8/17/20	8/21/20	200817093-01A	Chlordane	57-74-9	EPA 505	2	0.2	BDL
8/17/20	8/22/20	200817093-01B	Dalapon	75-99-0	EPA 515.4	200	1	BDL
8/17/20	8/29/20	200817093-01D	Di(2-ethylhexyl)adipate	103-23-1	EPA 525.2	400	0.6	BDL
8/17/20	8/29/20	200817093-01D	Di(2-ethylhexyl)phthalate	117-81-7	EPA 525.2	6	0.6	BDL
8/17/20	8/22/20	200817093-01B	Dinoseb	85-85-7	EPA 515.4	7	0.2	BDL
8/17/20	8/19/20	200817093-01G	Diquat	85-00-7	EPA 549.2	20	0.4	BDL
8/17/20	8/24/20	200817093-01F	Endothall	145-73-3	EPA 548.1	100	9	BDL
8/17/20	8/21/20	200817093-01A	Endrin	72-20-8	EPA 505	2	0.01	BDL
8/17/20	8/21/20	200817093-01	Ethylene dibromide	106-93-4	EPA 504.1	0.05	0.01	BDL
8/17/20	8/29/20	200817093-01D	Heptachlor	76-44-8	EPA 525.2	0.4	0.04	BDL
8/17/20	8/21/20	200817093-01A	Heptachlor epoxide	1024-57-3	EPA 505	0.2	0.02	BDL
8/17/20	8/21/20	200817093-01A	Hexachlorobenzene	118-74-1	EPA 505	1	0.1	BDL
8/17/20	8/21/20	200817093-01A	Hexachlorocyclopentadiene	77-47-4	EPA 505	50	0.1	BDL
8/17/20	8/21/20	200817093-01A	Lindane	58-89-9	EPA 505	0.2	0.02	BDL
8/17/20	8/21/20	200817093-01A	Methoxychlor	72-43-5	EPA 505	40	0.1	BDL
8/17/20	8/20/20	200817093-01E	Oxamyl	23135-22-0	EPA 531.1	200	1	BDL
8/17/20	8/22/20	200817093-01B	Pentachlorophenol	87-86-5	EPA 515.4	1	0.04	BDL
8/17/20	8/22/20	200817093-01B	Picloram	1918-02-1	EPA 515.4	500	0.1	BDL
8/17/20	8/21/20	200817093-01A	Polychlorinated biphenyl's	1336-36-3	EPA 505	0.5	0.1	BDL
8/17/20	8/29/20	200817093-01D	Simazine	122-34-9	EPA 525.2	4	0.07	BDL
8/17/20	8/21/20	200817093-01A	Toxaphene	8001-35-2	EPA 505	3	1	BDL

NT: Not Tested ug/L: Micrograms per Liter MCL: Maximum Contaminant Level BDL Below Laboratory MRL A less than sign (<) may also be used.

200817093-01 Y

2/2
8/31/20

Drinking Water Chain of Custody



Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Report To Information		Bill To Information (If different from report to)		Project Information	
Company Name: <u>MEADOW MTR WATER SUPPLY</u>		Company Name: _____		PWSID: <u>CO 207504</u>	
Contact Name: <u>ANDREW GRIFFITHS</u>		Contact Name: _____		System Name: <u>Meadow Mtr. Water Supply Co</u>	
Address: <u>P.O. Box 162</u>		Address: _____		Compliance Samples: Yes ☒ No ☐	
City: <u>ALLEN PARK</u> State: <u>CO</u> Zip: <u>80510</u>		City: _____ State: _____ Zip: _____		Send Results to CDPHE: Yes ☒ No ☐	
Phone: <u>(303) 747-2715</u>		Phone: _____		Task Number (Lab Use Only) CAL Task 200817093 JML	
Email: <u>andygus@earthlink.net</u>		Email: _____			
Sample Collector: <u>Andrew Griffiths</u>		Sample Collector Phone: <u>(303) 747-2715</u>			
Sample Collector Phone: _____		PO Number: _____			

			PHASE I, II, V Drinking Water Analyses (check requested analysis)																				Subcontract Analyses							
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)		Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite
8/17/20	9:45	001	15			X	X	X	X	X	X		X	X																
8/17/20	10:10	003 D.BP 001	A												X	X														
8/16/20	13:00	Non-Compliant Sample 1 NOT for state reporting HILL HOUSE															X													

Instructions:				C/S Info:				Seals Present Yes ☐ No ☐ Headspace Yes ☐ No ☐											
19 + 2 blanks																			
DBP sample name "Triple creek Ranch Oak Drive" per man				Delivered Via: <u>HD</u>				C/S Charge ☐											
Relinquished By: _____		Date/Time: _____		Received By: <u>Adama</u>		Date/Time: <u>8/17/20</u>		Relinquished By: <u>Adama</u>		Date/Time: <u>8/17/20</u>		Temp. <u>12</u> °C/Ice <u>Y</u>		Sample Pres. Yes ☒ No ☐		Received By: _____		Date/Time: _____	