

## Analytical Results

**TASK NO: 211220047**

**Report To:** Andrew Griffiths

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Bill To:** Rachel Barkworth

**Company:** Meadow Mountain Water Company  
P.O. Box 162  
Allenspark CO 80510

**Task No.:** 211220047  
**Client PO:**  
**Client Project:** Meadow Mtn Water Supply CO0207504

**Date Received:** 12/20/21  
**Date Reported:** 12/28/21  
**Matrix:** Water - Drinking

**Customer Sample ID** Brock

**Sample Date/Time:** 12/18/21 7:00 AM

**Lab Number:** 211220047-01

**Sample Point ID:** LCR002

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	<b>0.072</b>	EPA 200.8	0.001	1.3	12/23/21	QC54057	MBN
Lead (mg/L)	<b>BDL</b>	EPA 200.8	0.001	0.015	12/23/21	QC54057	MBN

### Abbreviations/ References:

RL = Reporting Limit = Minimum Level

mg/L = Milligrams Per Liter or PPM

ug/L = Micrograms Per Liter or PPB

mpn/100 mls = Most Probable Number Index/ 100 mls

Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.

(s) Spike amount low relative to the sample amount.

BDL = Not Detected at Reporting Limit.