

Analytical Results

TASK NO: 210623119

Report To: Andrew Griffiths

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Andrew Griffiths

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 210623119
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 6/23/21
Date Reported: 6/30/21
Matrix: Water - Drinking

Customer Sample ID Hames

Sample Date/Time: 6/19/21 3:00 PM

Lab Number: 210623119-05

Test	Result	Method	PQL	Date Analyzed	MCL
<u>Total</u>					
Copper (mg/L)	0.457	EPA 200.8	0.001	6/24/21	1.3
Lead (mg/L)	0.003	EPA 200.8	0.001	6/24/21	0.015

Abbreviations/ References:

PQL = Practical Quantification Limit
mg/L = Milligrams Per Liter or PPM
BDL = Below Detectable Levels
Date Analyzed = Date Test Completed



DATA APPROVED FOR RELEASE BY

10411 Heinz Way / Commerce City, CO 80640 / 303-659-2313
Mailing Address: P.O. Box 507 / Brighton, CO 80601-0507