

Analytical Results

TASK NO: 211101045

Report To: Andrew Griffiths

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510

Task No.: 211101045
Client PO:
Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 11/1/21
Date Reported: 11/8/21
Matrix: Water - Drinking

Customer Sample ID Neuton

Sample Date/Time: 10/31/21 7:30 AM

Lab Number: 211101045-02

Sample Point ID: LCR004

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	0.210	EPA 200.8	0.001	1.3	11/3/21	QC53125	MBN
Lead (mg/L)	0.004	EPA 200.8	0.001	0.015	11/3/21	QC53125	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
BDL = Not Detected at Reporting Limit.