

## **Analytical Results**

TASK NO: 211101045

Report To: Andrew Griffiths

Company: Meadow Mountain Water Company

P.O. Box 162

Allenspark CO 80510

Bill To: Rachel Barkworth

**Company:** Meadow Mountain Water Company

P.O. Box 162

Allenspark CO 80510

Task No.: 211101045

Client PO:

Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 11/1/21 Date Reported: 11/8/21

Matrix: Water - Drinking

Customer Sample ID Hans

**Sample Date/Time:** 10/31/21 7:00 AM

Lab Number: 211101045-01

Sample Point ID: LCR001

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<u>Total</u>							
Copper (mg/L)	0.074	EPA 200.8	0.001	1.3	11/3/21	QC53125	MBN
Lead (mg/L)	0.005	EPA 200.8	0.001	0.015	11/3/21	QC53125	MBN

1/3



## **Analytical Results**

TASK NO: 211101045

Report To: Andrew Griffiths

Company: Meadow Mountain Water Company

P.O. Box 162

Allenspark CO 80510

Bill To: Rachel Barkworth

Company: Meadow Mountain Water Company

P.O. Box 162

Allenspark CO 80510

Task No.: 211101045

Client PO:

Client Project: Meadow Mtn Water Supply CO0207504

Date Received: 11/1/21

Date Reported: 11/8/21 Matrix: Water - Drinking

Customer Sample ID Neuton

Sample Date/Time: 10/31/21 7:30 AM

Lab Number: 211101045-02

Sample Point ID: LCR004

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<u>Total</u>							
Copper (mg/L)	0.210	EPA 200.8	0.001	1.3	11/3/21	QC53125	MBN
Lead (mg/L)	0.004	EPA 200.8	0.001	0.015	11/3/21	QC53125	MBN



## Analytical QC Summary

TASK NO: 211101045

Report To: Andrew Griffiths

Company: Meadow Mountain Water Company

Receive Date: 11/1/21

Project Name: Meadow Mtn Water Supply CO0207504


Test	et QC Batch ID		Result		Method					
Copper	QC53125	Method Blank	ND		EPA 200.8					
Lead	QC53125	Method Blank	ND		EPA 200.8					
Test	QC Batch ID	QC Type	Limits	%Rec	RPD	Method				
Copper	QC53125	LCS	90 - 110	101.0	-	EPA 200.8				
		MS	70 - 130	116.6	-					
		MSD	0 - 10	-	3.7					
Lead	QC53125	LCS	90 - 110	106.3	-	EPA 200.8				
		MS	70 - 130	92.9	-					
		MSD	0 - 10	-	0.8					

All analyses were performed in accordance with approved methods under the latest revision to 40 CFR Part 136 unless otherwise identified. Based on my inquiry of the person or persons directly responsible for analyzing the wastewater samples and generating the report (s), the analyses, report, and information submitted are, to the best of my knowledge and belief, true, accurate, and complete.

DATA APPROVED FOR RELEASE BY

3/3

## **Drinking Water Chain of Custody**





Commerce City Lab 10411 Heinz Way Commerce City CO 80640

<u>Lakewood Service Center</u> 12860 W. Cedar Dr, Suite 100A Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Sample Co	ollector Pho	ne:(3°3)747-2715	PO Num	ber:									···			JAN														
	·····		.,		·	PH	ASE	I, II,	V D	rinki	ng V	ater	Ana	lyses	(che	ck r	eque	sted	anal	ysis)							Subc	ontra	ct Ana	ılyses
Date	Time	Client Sample ID / Sampl	le Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)		Gross Alpha/Beta	Radium 226/228	Radon	Uranium Chlorite
10/3//21	7am	HANS LCROO	) [	1						$\neg$		_						V			-	$\neg$	_	_	$\neg$	$\dashv$	$\neg$	-	$\dashv$	-
i0 31 21  0 31 21	7:30am	NEUTON LCRCX		1																		$\dashv$				$\dashv$		一十	$\dashv$	
1-1-1	* * * * * * * * * * * * * * * * * * *		<del>/</del>																							$\neg \uparrow$	_	十	$\neg \vdash$	1
																												_	1	1
											9"															$\exists$				
				J.																										
	Ì			<b>\$</b>																										
		(%																												
						$\mathcal{I}$																								
Instructio	ns:				~	-						Info:	Via:	ı	HL.	)	(	C/S C	harge		Seals	8	ent Y		No [			pace Y		No 🗆
Relinquish	ed Byż,	Date/Time:	Receiv	ed By	mA			Date.	/Time	age	4 of	Reli 4		shed I	By:				e/Tim				ceive					Date/		