

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
		OPER	NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
	24 Hr	Initials			deg C	<1	mg/L		>1.2mg/L	>7.3	PSI	PSI														
														Baseline TMP was 10 psi												
1	12:40	TW	0.69	6.8	2.0	0.026	1.5	7.5	1.4	7.2	75	72	12	11	11	10	12	12	12	12	12	12			30.1	3817261
2	11:10	MR	0.66	6.8	2.0	0.028	1.6	7.7	1.5	7.1	75	72	12	11	11	11	12	12	12	12	12	12			29.5	3818418
3	10:30	MR	0.76	6.8	2.0	0.027	1.6	7.7	1.5	7.1	75	72	12	11	11	11	12	12	12	11	12	12			30.6	3819663
4	11:45	MR	0.74	6.8	2.0	0.026	1.5	7.6	1.4	7.1	75	72	12	11	11	11	11	12	11	11	12	11			30.8	3821009
5	9:10	BM	0.57	6.8	2.0	0.027	1.7	7.8	1.5	7.4	75	72	12	11	11	11	11	11	11	11	12	12	X		30.0	3822002
6	9:15	BM	0.57	6.8	1.5	0.028	1.5	7.8	1.4	7.3	75	72	12	12	11	11	11	11	12	11	12	11			30.8	3823155
7	9:10	BM	0.70	6.8	2.0	0.027	1.5	7.9	1.4	7.5	75	72	11	11	11	11	11	11	12	11	12	11			30.4	3824253
8	11:05	TW	0.61	6.8	2.0	0.027	1.7	7.8	1.5	7.4	75	72	11	10	10	10	11	11	12	12	13	12			30.3	3825550
9	10:40	MR	0.68	6.8	1.5	0.028	1.7	7.6	1.5	7.1	75	69	12	11	11	11	12	12	12	11	12	12			30.6	3826745
10	10:30	MR	0.72	6.8	1.5	0.027	1.6	7.6	1.4	7.1	75	72	12	11	11	11	12	12	12	12	12	12			29.6	3827848
11	10:10	MR	0.92	6.8	1.5	0.028	1.7	7.7	1.4	7.1	75	72	12	11	11	11	12	11	12	12	12	12			30.3	3829021
12	9:40	BM	0.81	6.8	1.5	0.027	1.7	7.8	1.4	7.3	75	69	12	11	11	11	11	11	11	11	12	11	X	X	30.6	3830147
13	8:50	BM	0.94	6.8	1.5	0.027	1.7	7.7	1.5	7.3	75	72	11	11	11	11	11	11	11	11	11	11			30.5	3832141
14	10:10	BM	0.70	6.8	1.5	0.027	1.7	7.6	1.4	7.3	75	72	12	11	11	11	11	11	12	11	11	11			30.3	3834605
15	11:50	TW	0.63	6.8	1.0	0.027	1.7	7.5	1.4	7.2	75	71	14	11	12	11	12	12	12	11	12	12			30.5	3837077
16	13:00	MR	0.87	6.8	1.5	0.027	1.6	7.6	1.3	7.1	75	72	12	11	11	11	12	12	12	11	12	12			30.1	3839727
17	11:00	MR	0.71	6.8	1.5	0.027	1.6	7.7	1.4	7.2	75	71	11	10	10	10	11	12	11	11	12	12			29.2	3841882
18	15:20	MR	0.75	6.8	1.5	0.027	1.6	7.6	1.4	7.1	75	71	11	10	10	10	11	11	11	11	12	12			29.7	3844939
19	09:00	BM	0.74	6.8	1.5	0.027	1.7	8.0	1.4	7.4	75	73	11	11	11	10	11	11	12	11	11	11	X		32.3	3846468
20	08:30	BM	0.81	6.8	1.5	0.027	1.5	8.1	1.5	7.5	75	72	12	11	10	10	11	11	12	11	11	11			29.3	3848735
21	08:55	BM	0.77	6.8	1.5	0.027	1.5	7.6	1.4	7.6	75	72	11	10	10	10	11	12	11	11	12	12			30.4	3851134
22	11:40	TW	0.66	6.8	1.5	0.027	1.6	7.5	1.4	7.2	74	72	13	11	11	11	13	12	13	11	12	12			30.5	3853850
23	10:40	MR	0.69	6.8	1.5	0.027	1.5	7.6	1.4	7.1	75	72	12	11	10	10	11	11	11	11	12	12			29.4	3856264
24	14:00	MR	0.72	6.8	1.5	0.027	1.6	7.7	1.3	7.1	75	72	12	11	11	11	12	11	11	11	12	12			29.7	3858902
25	10:30	MR	0.81	6.8	1.5	0.027	1.6	7.8	1.3	7.1	75	73	12	11	11	11	11	11	12	11	12	12			29.2	3860933
26	9:20	BM	0.64	6.8	1.5	0.028	1.5	7.9	1.5	7.5	74	72	12	12	12	11	11	12	12	12	12	12	X	X	30.5	3863183
27	9:05	BM	0.67	6.9	1.5	0.027	1.6	8.0	1.5	7.4	75	72	11	10	10	10	10	11	11	10	11	11			30.0	3865577
28	9:35	BM	0.57	6.8	1.5	0.027	1.6	8.0	1.5	7.2	75	72	11	11	10	10	11	11	11	11	11	11			29.8	3868008
29	11:30	TW	0.71	6.8	1.5	0.027	1.6	7.5	1.5	7.1	75	72	12	11	11	11	13	11	12	12	12	13			31.0	3870852
30	15:40	MR	0.84	6.8	1.5	0.027	1.7	7.8	1.4	7.2	75	72	12	11	11	11	11	12	11	11	12	12			29.7	3873944
31	10:10	MR	0.73	6.8	1.5	0.027	1.7	7.8	1.5	7.2	75	72	12	11	11	11	11	11	11	11	12	12			30.4	3875978

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F -	Clear well Level - Daily				
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP		Gallons	
1	12:40	TW															5600		
2	11:10	AE															5700		
3	10:30	AE															5800		
4	11:45	AE															5800		
5	9:10	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X		5700		
6	9:15	Bm															5600		
7	9:00	Bm															5800	RAW-6.8 DISTR-75	
8	11:05	TW															5700		
9	10:40	AE															5700		
10	10:30	AE															5800		
11	10:40	AE															5600		
12	9:40	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5600		
13	8:50	Bm															5800		
14	10:10	Bm															5700	RAW-6.8 DISTR-75	
15	11:50	TW															5700		
16	13:00	AE															5800		
17	11:00	AE															5800		
18	15:20	AE															5800		
19	09:40	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X		5700		
20	08:30	Bm															5700		
21	08:55	Bm															5600	RAW-6.8 DISTR-76	
22	11:40	TW															5600		
23	10:40	AE															5800		
24	14:00	AE															5600		
25	10:30	AE															5800		
26	9:20	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5700		
27	9:05	Bm															5700		
28	9:35	Bm															5800	RAW-6.8 DISTR-72	
29	11:30	TW															5600		
30		AW															5600		
31		AW															5800		

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete