

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser	
		OPER	NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd	
	24 Hr	Initials			deg C	<.1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi.														
1	10:40	Mr	0.71	6.8	1.2	0.027	1.6	7.6	1.4	7.1	75	72	12	11	11	11	11	12	12	11	12	12			30.7	3878711	
2	9:05	Bm	0.87	6.8	1.5	0.027	1.6	8.1	1.4	7.5	75	72	11	11	11	11	11	11	11	11	11	12	X		29.7	3881112	
3	9:40	Bm	0.81	6.8	1.5	0.027	1.6	7.9	1.5	7.2	75	72	11	10	10	10	11	11	11	11	11	11			29.3	3883782	
4	8:55	Bm	0.91	6.8	1.5	0.027	1.7	8.0	1.5	7.2	75	72	11	10	10	10	10	11	11	10	11	11			32.6	3886280	
5	12:20	Mr	0.59	6.8	1.5	0.027	1.7	7.8	1.5	7.2	75	72	13	11	11	12	12	12	12	12	12	13			29.7	3889276	
6	10:20	Mr	0.60	6.8	1.5	0.027	1.7	7.7	1.3	7.1	75	73	12	11	10	10	11	11	11	11	11	12			29.3	3891696	
7	10:20	Mr	0.77	6.8	1.2	0.027	1.6	7.8	1.4	7.1	75	72	12	11	10	11	11	11	12	11	12	12			29.1	3894377	
8	11:50	Mr	0.81	6.8	1.5	0.027	1.6	7.8	1.3	7.1	75	72	12	11	11	11	11	11	12	11	12	12			29.5	3897418	
9	9:10	Bm	0.79	6.8	1.5	0.027	1.6	7.9	1.5	7.3	75	72	11	10	10	11	11	11	11	10	11	11	X	X	30.2	3899637	
10	9:50	Bm	0.79	6.8	1.5	0.027	1.6	7.8	1.3	7.3	75	72	11	10	10	10	11	11	12	12	12	12			30.3	3902261	
11	8:50	Bm	0.57	6.8	2.0	0.027	1.6	8.0	1.5	7.2	75	72	10	10	10	11	11	11	12	11	12	12			31.4	3904743	
12	11:50	Mr	0.65	6.8	1.5	0.027	1.7	7.8	1.4	7.4	75	72	11	10	11	10	11	11	11	11	12	12			30.1	3908037	
13	10:30	Mr	0.56	6.8	1.5	0.027	1.6	7.7	1.3	7.1	75	72	12	10	10	10	11	11	11	11	12	12			29.8	3910196	
14	10:30	Mr	0.69	6.8	1.5	0.027	1.6	7.8	1.4	7.1	75	72	12	11	11	11	12	12	11	11	12	12			29.5	3912871	
15	9:20	Mr	0.59	6.8	1.2	0.027	1.7	7.8	1.4	7.1	75	72	12	10	11	10	11	12	12	12	12	12			29.4	3915727	
16	9:55	Bm	0.73	6.8	1.0	0.027	1.7	8.0	1.4	7.2	75	72	11	11	11	11	11	11	11	11	12	11	X		29.4	3918773	
17	8:15	Bm	0.68	6.8	1.0	0.027	1.7	8.0	1.3	7.2	75	72	11	10	10	10	10	10	11	10	11	11			28.2	3921161	
18	8:25	Bm	0.62	6.8	1.0	0.027	1.6	8.1	1.5	7.4	75	72	11	10	10	10	11	10	11	10	11	11			28.4	3923722	
19	8:40	Mr	0.60	6.8	1.0	0.027	1.7	8.0	1.4	7.4	71	69	14	11	11	11	13	12	13	13	13	13			30.3	3926293	
20	11:20	Mr	0.60	6.8	1.5	0.027	1.5	7.6	1.3	7.1	75	72	12	11	11	10	11	11	11	11	12	12			29.1	3929263	
21	11:30	Mr	0.69	6.8	1.5	0.027	1.5	7.7	1.3	7.1	75	69	11	10	10	10	10	10	10	10	11	11			27.9	3932127	
22	9:50	Mr	0.79	6.8	1.5	0.027	1.5	7.8	1.3	7.3	75	72	11	10	10	10	10	11	11	10	11	11			27.5	3934214	
23	8:10	Bm	0.83	6.8	1.5	0.027	1.6	8.1	1.3	7.3	75	72	11	10	10	10	11	11	11	11	11	11	X	X	27.8	3936564	
24	8:50	Bm	0.61	6.8	1.2	0.027	1.5	8.0	1.4	7.3	75	72	11	10	10	10	11	11	11	11	11	11			30.4	3939157	
25	9:10	Bm	0.71	6.8	1.2	0.027	1.5	8.0	1.4	7.3	75	72	11	10	10	10	11	11	12	11	11	11			29.4	3941750	
26	10:00	Mr	0.69	6.8	1.2	0.027	1.5	7.6	1.4	7.2	75	72	13	11	11	11	12	12	13	12	12	12			29.9	3944349	
27	11:20	Mr	0.73	6.8	1.5	0.027	1.5	7.8	1.2	7.1	75	72	12	11	10	10	11	11	11	11	12	12			29.6	3947152	
28	9:20	Mr	0.74	6.8	1.2	0.027	1.6	7.6	1.4	7.1	75	72	12	11	11	11	12	12	12	11	12	12			29.4	3949394	
29																											
30																											
31																											

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp °F	Clear well Level - Daily	Gallons					
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP			
1	10:40	MR																	5600		
2	9:05	BM	X		X		X		X		X		X		X		X		5700		
3	9:40	BM																	5600		
4	8:55	BM																	5600	RAW-6-8 DISTR-7.2	
5	12:20	TW																	5600		
6	10:20	MR																	5600		
7	10:20	MR																	5600		
8	11:50	MR																	5700		
9	9:10	BM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5600		
10	9:50	BM																	5900		
11	8:50	BM																	5900	RAW 6-8 DISTR-7.2	
12	14:50	MR																	5700		
13	10:30	MR																	5700		
14	10:30	MR																	5700		
15	9:20	MR																	5800		
16	9:55	BM	X		X		X		X		X		X		X		X		5700		
17	8:15	BM																	5800		
18	8:25	BM																	5500	RAW-6-8 DISTR-7.4	
19	8:40	TW																	5300		
20	11:20	MR																	5700		
21	14:30	MR																	5800		
22	9:50	MR																	5700		
23	8:10	BM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5800		
24	8:50	BM																	5700		
25	8:10	BM																	5600	RAW-6-8 DISTR-7.3	
26	10:00	TW																	6000		
27	11:20	MR																	5700		
28	9:20	MR																	6000		
29																					
30																					
31																					

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete

Note: MIT - Pass (P) or Fail (F)

Note: CIP - X for complete