

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
		OPER	NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
	24 Hr	Initials			deg C	<.1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi													
1	15:10	Mr	0.87	6.8	1.2	0.027	1.5	7.6	1.3	7.1	75	72	12	11	11	11	12	12	12	11	12	12			30.3	3952569
2	09:40	Bm	0.62	6.8	1.5	0.027	1.5	8.0	1.4	7.3	75	72	12	11	11	11	12	11	12	11	12	12	X		30.4	3954476
3	09:15	Bm	0.62	6.8	1.5	0.027	1.6	8.0	1.4	7.3	75	72	11	10	11	11	11	11	12	11	11	12			29.1	3957032
4	09:35	Bm	0.60	6.8	2.0	0.027	1.7	7.9	1.5	7.2	75	72	12	11	11	11	11	12	11	11	11	12			29.4	3959611
5	11:00	Mr	0.62	6.8	2.0	0.027	1.7	7.5	1.4	7.2	75	72	15	11	12	12	13	13	12	13	12	13			30.1	3962333
6	14:10	Mr	0.67	6.8	1.5	0.027	1.7	7.7	1.4	7.1	75	72	12	10	10	10	10	11	11	11	12	12			29.3	3965267
7	10:00	Mr	0.71	6.8	1.5	0.027	1.8	7.6	1.4	7.1	76	73	12	11	11	11	12	11	12	11	12	12			29.4	3967381
8	09:50	Mr	0.85	6.8	2.0	0.027	1.8	7.7	1.4	7.1	75	72	12	11	11	11	11	11	12	12	12	12			29.3	3969968
9	09:10	Bm	0.69	6.8	1.5	0.027	1.6	8.0	1.4	7.3	75	72	11	11	11	11	12	11	11	11	12	11	X	X	29.3	3972482
10	09:20	Bm	0.54	6.8	1.5	0.027	1.6	7.9	1.4	7.2	75	72	12	11	11	10	11	11	12	11	11	12			30.0	3975034
11	09:30	Mr	0.57	6.8	1.0	0.027	1.7	7.8	1.4	7.1	75	72	12	11	11	10	12	11	11	11	12	12			29.4	3977698
12	07:30	Mr	0.61	6.8	1.5	0.027	1.7	7.5	1.5	7.1	75	72	13	11	11	11	11	12	12	12	12	13			29.3	3979915
13	10:00	Mr	0.75	6.8	1.0	0.027	1.7	7.6	1.3	7.1	75	69	11	10	10	10	11	11	11	11	11	12			29.8	3982885
14	14:50	Mr	0.78	6.8	1.0	0.027	1.6	8.6	1.4	7.1	75	72	12	11	11	11	11	11	12	11	12	12			28.2	3985848
15	11:30	Mr	0.88	6.8	1.5	0.027	1.5	7.6	1.4	7.1	75	72	12	11	11	11	11	12	12	11	12	12			29.8	3987988
16	09:20	Mr	0.63	6.8	1.5	0.027	1.5	7.6	1.4	7.1	75	72	12	11	11	11	11	12	12	12	12	12	X		29.0	3990272
17	09:50	Mr	0.82	6.8	1.5	0.027	1.5	7.6	1.3	7.1	75	72	12	11	11	11	11	11	12	11	12	12			30.2	3992864
18	13:20	Mr	0.88	6.8	1.5	0.027	1.5	7.8	1.3	7.1	75	72	12	11	11	11	11	12	12	12	12	12			28.8	3995764
19	10:15	Mr	0.60	6.8	1.75	0.027	1.6	7.5	1.4	7.1	76	72	13	13	11	11	13	11	12	12	12	13			29.3	3997887
20	09:20	Mr	0.57	6.8	2.0	0.027	1.5	7.4	1.4	7.1	75	72	12	11	11	11	12	11	14	12	12	12			29.4	4000380
21	11:00	Mr	0.66	6.8	2.0	0.027	1.4	7.6	1.4	7.1	75	72	12	11	11	11	12	12	12	12	12	12			29.6	4003200
22	10:00	Mr	0.63	6.8	1.5	0.027	1.6	7.9	1.4	7.3	75	72	12	11	11	11	12	11	12	12	12	12			29.2	4005620
23	09:40	Bm	0.65	6.8	1.5	0.026	1.4	8.5	1.5	7.7	75	72	12	12	11	11	12	12	12	12	12	12	X	X	30.1	4008008
24	09:45	Bm	0.70	6.8	1.5	0.025	1.4	8.2	1.4	7.7	75	71	12	11	11	11	11	12	12	11	12	12			30.8	4010544
25	09:20	Bm	0.88	6.8	1.5	0.025	1.5	7.6	1.4	7.2	75	71	11	11	10	10	11	12	12	11	11	11			29.5	4022995
26	09:45	Mr	0.71	6.8	1.5	0.024	1.5	7.5	1.4	7.1	75	71	13	11	12	11	13	12	13	12	12	13			30.9	4015353
27	13:00	Mr	0.75	6.8	1.5	0.025	1.5	7.5	1.4	7.1	75	71	12	11	11	11	12	12	12	12	12	12			31.4	4018533
28	15:40	Mr	0.72	6.8	2.0	0.025	1.4	7.6	1.3	7.1	75	72	12	11	11	11	12	12	12	12	12	12			30.7	40214385
29	09:40	Mr	0.75	6.8	2.0	0.026	1.5	7.5	1.3	7.0	75	72	12	11	11	10	11	12	12	12	12	12			29.3	4023430
30	09:05	Bm	0.68	6.8	2.0	0.026	1.5	7.8	1.4	7.2	75	69	11	11	11	10	11	11	12	12	11	12	X		29.2	4025775
31	09:40	Bm	0.69	6.8	1.5	0.026	1.5	7.6	1.5	7.2	75	72	11	10	10	10	11	10	11	10	12	12			30.8	4028349

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F -	Clear well Level - Daily								
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	Gallons		
1	15:10	AG																			5600		
2	0900	BM	X		X		X		X		X		X		X		X		X		5600		
3	0915	BM																			5500		
4	0935	BM																			5900	RAW 6-8 DISR-7.2	
5	1100	TW																			6000		
6	14:10	MR																			5600		
7	10:00	MR																			5700		
8	0900	BM																			5800		
9	0910	BM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5700		
10	09:20	BM																			5700		
11	09:30	MR																			6000	RAW 6-8 DISR-7.2	
12	0730	TW																			5800		
13	10:00	MR																			5900		
14	14:50	MR																			5800		
15	11:30	MR																			5700		
16	09:20	MR	X		X		X		X		X		X		X		X		X		5600		
17	09:50	MR																			5700		
18	1300	-																			5800	RAW 6-8 DISR-7.2	
19	10:15	TW																			5800		
20	09:20	MR																			5600		
21	11:00	MR																			5800		
22	10:00	MR																			5900		
23	0940	BM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5600		
24	0945	BM																			5700	RAW 6-8 DISR-7.2	
25	0945	TW																			5600		
26	13:00	MR																			5700		
27	15:40	MR																			5600		
28	09:40	MR																			5700		
29																					5700		
30	0915	BM	X		X		X		X		X		X		X		X		X		5600		
31	0940	BM																			5900		

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete

Note: MIT - Pass (P) or Fail (F)

Note: CIP - X for complete