

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
		OPER	NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
	24 Hr	Initials			deg C	<1	mg/L		>1.2mg/L	>7.3	PSI	PSI														
Baseline TMP was 10 psi																										
1	0830	Bm	0.60	6.8	1.5	0.026	1.5	7.9	1.5	7.5	75	72	11	10	10	10	11	11	11	10	11	12			29.1	4030740
2	1125	TW	0.64	6.8	1.5	0.026	1.5	7.5	1.4	7.1	75	72	12	11	11	11	13	12	13	12	12	13			30.1	4033685
3	1000	MR	0.70	6.7	2.0	0.026	1.5	7.5	1.3	7.1	75	72	12	11	11	10	12	11	11	11	12	12			29.4	4036123
4	1040	MR	0.93	6.8	2.0	0.026	1.5	7.6	1.2	7.1	75	72	12	11	11	11	12	11	11	11	12	12			29.0	4038731
5	9:56	MR	1.01	6.8	2.0	0.026	1.5	7.6	1.2	7.1	75	72	12	11	11	11	11	11	11	12	12	12			29.3	4040272
6	9:40	Bm	1.06	6.8	2.0	0.026	1.5	7.8	1.4	7.2	75	72	12	11	11	10	12	11	11	11	11	11	X	X	29.2	4043712
7	9:45	Bm	1.20	6.8	2.0	0.027	1.4	7.8	1.4	7.1	75	72	11	10	10	10	11	11	12	11	11	11			29.8	4046348
8	9:25	Bm	1.14	6.8	2.0	0.026	1.5	7.5	1.4	7.2	75	72	11	10	11	10	12	11	12	11	11	11			29.4	4048859
9	11:45	TW	1.15	6.8	2.0	0.026	1.7	7.5	1.4	7.2	75	72	12	11	11	11	12	11	12	11	12	11			29.4	4051678
10	10:40	MR	1.33	6.8	2.0	0.026	1.6	7.8	1.4	7.1	75	72	12	11	11	10	12	11	12	11	12	12			29.0	4054140
11	10:30	MR	1.34	6.8	2.0	0.026	1.6	7.7	1.3	7.1	75	72	12	11	11	10	12	11	12	11	12	12			29.6	4056749
12	11:10	MR	1.12	6.8	1.8	0.026	1.7	7.7	1.4	7.1	75	72	12	10	11	10	12	11	12	11	12	12			29.3	4058946
13	9:40	Bm	0.97	6.8	1.5	0.026	1.6	8.0	1.5	7.4	75	72	12	11	11	10	12	12	12	11	11	11			28.2	4060927
14	8:50	Bm	0.93	6.8	2.0	0.026	1.8	7.8	1.5	7.3	75	72	12	11	11	10	12	11	12	11	12	11	X		28.4	4062430
15	8:40	Bm	0.98	6.8	2.0	0.026	1.6	8.2	1.5	7.2	75	72	11	10	11	10	11	11	12	10	11	11			28.6	4063953
16	10:40	TW	0.96	6.8	1.5	0.024	1.7	7.5	1.5	7.1	75	72	12	11	11	11	12	12	13	11	12	13			30.3	4065635
17	9:50	MR	1.13	6.8	2.0	0.026	1.6	7.8	1.4	7.1	75	72	12	11	11	10	12	12	12	11	11	12			30.2	4067082
18	3:20	MR	0.94	6.8	2.0	0.026	1.7	7.7	1.4	7.1	75	73	12	11	11	10	11	11	12	11	11	12			28.5	4069070
19	9:15	MR	0.91	6.8	2.0	0.026	1.6	7.6	1.3	7.1	75	72	12	11	11	10	12	11	12	11	12	12			32.6	4070236
20	9:35	Bm	0.71	6.8	1.5	0.026	1.7	8.0	1.5	7.3	76	73	11	10	11	10	11	11	12	11	11	12	X	X	25.8	4071788
21	8:50	Bm	0.60	6.8	1.5	0.026	1.7	8.0	1.5	7.3	75	71	11	10	10	10	11	11	11	11	10	11			29.4	4073193
22	9:00	Bm	0.70	6.8	1.5	0.026	1.6	8.0	1.4	7.3	75	72	11	10	10	10	11	10	11	11	10	11			27.8	4074573
23	08:45	TW	0.65	6.8	2.0	0.024	1.8	7.5	1.3	7.2	76	73	11	11	10	10	12	10	12	11	11	12			25.9	4075960
24	9:45	MR	0.86	6.8	2.0	0.026	1.5	7.8	1.3	7.1	75	72	11	10	10	10	11	10	11	10	10	11			28.5	4077548
25	12:30	MR	0.77	6.8	2.4	0.026	1.5	7.8	1.3	7.0	75	72	11	10	10	10	11	10	10	10	10	11			28.7	4079317
26	8:45	MR	0.88	6.8	2.2	0.026	1.5	7.8	1.3	7.1	75	73	11	10	10	10	11	10	10	10	10	11			27.5	4080553
27	9:40	Bm	1.29	6.8	2.5	0.027	1.5	7.9	1.4	7.2	75	73	10	10	10	10	10	11	11	11	11	11			28.7	4082030
28	14:10	Bm	1.29	6.8	2.0	0.028	1.5	7.9	1.3	7.2	76	73	10	10	10	10	11	10	11	10	10	11	X		25.9	4083695
29	10:10	Bm	1.26	6.8	2.5	0.028	1.6	8.0	1.2	7.1	76	73	11	10	10	10	12	11	11	11	11	12			27.6	4084901
30	12:00	TW	1.32	6.8	2.5	0.031	1.8	7.5	1.2	7.1	76	73	11	11	11	11	13	12	13	12	11	13			27.1	4086424
31																										

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

IWT UF SERIES
WEEKLY INTEGRITY TESTING
TESTING, AS NEEDED.

Meadow Mountain Water Supply Company

MONTH 04 YEAR 2020

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F -	Clear well Level - Daily								
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	Gallons		
1	8:30	Bm																			5600	RAW-6.9 DISTR-7.5	
2	9:15	TW																			5600		
3	10:00	AK																			5700		
4	10:40	AK																			5900		
5	9:56	AK																			5800		
6	09:00	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5800		
7	09:45	Bm																			5900		
8	09:30	Bm																			5700	RAW-6.9 DISTR-7.2	
9	11:45	TW																			5800		
10	10:40	AK																			5800		
11	10:30	AK																			5900		
12	11:10	AK																			5800		
13	9:40	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5900		
14	8:50	Bm																			5500		
15	8:40	Bm																			5500	RAW-6.9 DISTR-7.2	
16	10:50																				5700		
17	9:50	AK																			5600		
18	3:20	AK																			5600		
19	9:15	AK																			5700		
20	9:35	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5800		
21	8:50	Bm																			5500		
22	8:00	Bm																			5700	RAW 6.9 DISTR-7.3	
23	08:45	TW																			5600		
24	9:15	AK																			5900		
25	12:20	AK																			5800		
26	8:45	AK																			5700		
27	9:40	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	5600		
28	14:10	Bm																			5700		
29	10:10	Bm																			5900	RAW 6.9 DISTR 7.1	
30	12:00	TW																			6000		
31																							

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete

Note: MIT - Pass (P) or Fail (F)

Note: CIP - X for complete