

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
		OPER	NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
	24 Hr	Initials			deg C	<1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi													
1	9:45	Bm	0.70	6.8	7.5	0.029	2.0	8.0	1.4	7.5	74	71	11	10	11	11	11	11	11	12	12	12			33.4	4158101
2	08:10	TW	0.76	6.8	7.0	0.029	2.0	7.5	1.5	7.3	74	71	11	11	11	12	13	11	12	13	13	13			33.3	4159280
3	11:30	MT	0.99	6.8	7.5	0.029	2.0	7.8	1.3	7.3	74	71	11	10	11	10	11	11	11	12	12	12			31.9	4160997
4	10:20	MT	0.82	6.8	7.5	0.028	1.8	7.8	1.2	7.2	74	71	11	10	10	10	11	11	11	11	12	12			33.0	4162272
5	9:30	MT	0.75	6.8	7.5	0.029	1.9	7.8	1.4	7.2	74	71	11	10	10	11	11	11	11	11	12	12			32.6	4163579
6	8:40	Bm	1.16	6.8	7.0	0.028	1.9	8.0	1.4	7.4	74	71	11	10	11	11	11	11	11	12	12	11	X	X	32.8	4164863
7	8:10	Bm	0.85	6.8	7.5	0.028	1.6	7.9	1.4	7.6	74	71	12	10	11	11	12	10	11	12	12	12			33.4	4166082
8	8:35	Bm	0.59	6.8	7.5	0.028	1.7	8.0	1.4	7.6	74	71	12	10	11	11	12	11	11	12	11	12			33.3	4167496
9	11:55	TW	1.02	6.8	8.0	0.028	1.7	7.5	1.3	7.3	74	71	13	11	12	11	12	12	12	12	12	13			34.1	4169053
10	8:00	MT	0.70	6.8	7.5	0.027	1.6	7.8	1.3	7.2	74	71	12	10	11	11	11	11	11	12	12	12			32.5	4170137
11	11:15	MT	0.69	6.8	8.0	0.028	1.5	7.8	1.2	7.3	74	71	11	10	11	10	11	11	11	11	12	12			33.5	4171839
12	8:15	MT	0.61	6.8	7.8	0.028	2.0	7.8	1.5	7.3	74	70	11	10	11	10	11	11	11	12	12	12			33.8	4173046
13	10:15	MT	0.65	6.8	7.8	0.028	1.9	7.6	1.4	7.3	74	70	11	11	11	11	11	11	11	12	12	12			33.2	4174445
14	10:15	MT	0.81	6.8	8.0	0.028	1.7	7.7	1.4	7.2	74	70	11	10	11	10	11	11	11	11	12	12	X		34.5	4175852
15	18:20	MT	0.88	6.8	8.5	0.029	1.8	7.7	1.2	7.3	74	70	11	10	10	10	11	10	11	11	12	12			33.6	4177613
16	07:45	TW	0.77	6.8	8.5	0.030	1.9	7.6	1.3	7.3	74	70	12	11	11	11	12	11	11	12	12	12			33.9	4178310
17	09:40	Bm	1.64	6.8	8.5	0.028	1.6	8.0	1.5	7.4	73	69	11	10	10	10	11	10	10	12	11	11			33.0	4179843
18	08:00	Bm	0.73	6.8	8.0	0.029	1.7	8.1	1.5	7.4	75	71	11	12	10	11	11	11	10	11	12	11			33.5	4181143
19	08:40	Bm	0.83	6.8	7.5	0.028	1.7	8.0	1.4	7.5	74	70	11	11	11	11	11	11	11	11	11	12			33.3	4182641
20	08:55	Bm	0.62	6.8	8.6	0.029	1.7	7.9	1.4	7.4	74	71	11	10	11	10	12	11	12	11	11	12	X		34.1	4184152
21	09:15	Bm	0.58	6.8	8.5	0.029	1.7	7.9	1.4	7.4	74	68	11	10	11	11	11	11	11	12	12	11			33.8	4185538
22	08:40	Bm	0.52	6.8	8.5	0.029	1.7	7.7	1.4	7.3	74	68	11	11	11	11	11	11	12	11	12	11			33.2	4186932
23	08:20	TW	0.64	6.9	8.5	0.028	1.4	7.5	1.5	7.3	74	70	12	11	12	12	12	11	12	13	13	13			34.2	4188454
24	13:30	MT	0.62	6.9	9.0	0.030	1.7	7.6	1.3	7.3	74	70	11	10	11	11	11	11	12	12	12	12			34.1	4190549
25	14:20	MT	0.87	6.9	9.0	0.030	1.7	7.8	1.3	7.3	74	68	11	11	11	10	11	11	11	12	12	12			33.8	4191714
26	8:35	MT	0.65	6.9	8.5	0.032	1.5	7.6	1.4	7.3	74	71	12	11	12	11	11	11	12	12	12	12			33.7	4192783
27	8:35	Bm	0.54	6.8	8.5	0.031	1.5	7.6	1.2	7.1	74	71	12	11	11	11	12	12	12	11	12	12	X	X	33.2	4194241
28	8:30	Bm	0.50	6.8	8.5	0.030	1.4	7.8	1.3	7.4	74	71	11	10	11	11	11	11	11	11	12	12			34.3	4195273
29	7:35	Bm	0.71	6.8	8.5	0.028	1.5	7.9	1.4	7.4	74	71	12	11	12	12	11	11	11	11	12	11			33.9	4197562
30	08:25	TW	0.51	6.7	8.5	0.028	1.6	7.6	1.3	7.3	74	71	12	10	11	11	12	11	11	12	12	12			34.4	4198855
31	10:00	MT	0.54	6.8	8.5	0.028	1.6	7.6	1.3	7.3	74	71	11	10	10	10	11	10	11	11	12	11			32.6	4200385

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

DAY	TIME	CERTIFIED OPERATOR	UF																				Distribution Entry Point			Comments
			1	2	3	4	5	6	7	8	9	10	MIT CIP		MIT CIP		MIT CIP		MIT CIP		MIT CIP		Weekly	temp °F	Clear well Level - Daily	
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP			Gallons	
1	9:45	BPM																							5600	RAW 6.8 PISTR - 7.5
2	08:16	TW																							6000	
3	11:30	MR																							5800	
4	10:20	MR																							5900	
5	9:30	MR																							5800	
6	08:40	BPM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X			6000	
7	08:10	BPM																							5800	
8	08:55	BPM																							5600	RAW-6.8 PISTR - 7.6
9	11:55	TW																							6000	
10	08:00	MR																							5800	
11	11:15	MR																							5600	
12	08:15	MR																							5900	
13	10:15	MR																							5900	
14	10:15	MR	X		X		X		X		X		X		X		X		X		X				5700	
15	18:20	MR																							5600	RAW 6.8 PISTR - 7.3
16	07:45	TW																							6000	
17	09:00	BPM																							5500	
18	08:00	BPM																							5600	
19	08:40	BPM																							5900	
20	08:55	BPM	X		X		X		X		X		X		X		X		X		X				5800	
21	09:15	BPM																							5700	
22	08:40	BPM																							5900	RAW-6.8 PISTR - 7.3
23	08:20	TW																							6000	
24	18:00	MR																							5900	
25	14:20	MR																							5800	
26	08:35	MR																							5600	
27	9:35	BPM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X			5500	
28	8:20	BPM																							5500	
29	9:35	BPM																							5900	RAW 6.8 PISTR - 7.4
30	08:15	TW																							5800	
31	10:00	MR																							5700	

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete