

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
			24 Hr	Initials	deg C	<1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi													
1	16:30	AK	0.77	6.8	9.0	0.028	1.6	7.6	1.2	7.3	74	71	11	10	11	10	10	10	11	11	11	11			32.9	4201981
2	7:20	AK	0.61	6.8	8.5	0.028	1.8	7.8	1.3	7.3	74	71	11	10	10	11	11	10	11	11	12	12			32.0	4202741
3	9:35	Bm	0.54	6.8	9.5	0.028	1.8	7.9	1.5	7.6	75	72	12	11	12	11	12	11	12	12	12	12	X		31.6	4204180
4	9:00	Bm	0.63	6.8	9.0	0.029	1.8	8.0	1.3	7.3	74	71	11	10	11	11	11	10	11	11	11	11			32.6	4205463
5	9:00	Bm	0.57	6.8	8.5	0.028	1.8	7.8	1.3	7.3	75	72	11	10	11	10	11	10	11	11	11	11			32.7	4206790
6	11:30	TW	0.65	6.9	8.5	0.027	1.8	7.5	1.5	7.3	74	70	13	10	11	11	11	11	11	12	13	13			32.7	4208265
7	9:55	AK	0.80	6.8	8.0	0.028	1.8	7.5	1.4	7.2	74	71	11	10	11	10	10	10	10	11	12	11			32.3	4208516
8	10:25	AK	0.81	6.8	8.5	0.027	1.8	7.7	1.3	7.2	74	71	10	10	10	10	10	10	10	10	11	11			31.7	421034
9	8:35	AK	0.59	6.8	8.5	0.027	1.7	7.6	1.2	7.3	74	70	11	10	10	10	11	11	11	11	12	11			33.4	4212189
10	9:10	Bm	0.96	6.8	8.5	0.028	1.7	7.7	1.5	7.5	74	71	11	10	11	12	12	11	11	12	13	12	X		34.3	4213796
11	7:30	Bm	0.48	6.8	8.5	0.028	1.7	7.8	1.4	7.4	74	71	11	10	11	11	11	10	11	12	11	11			32.8	4215015
12	12:30	Bm	0.32	6.8	9.0	0.028	1.7	7.8	1.5	7.4	75	71	11	10	11	11	11	11	11	11	12	11			33.4	421678
13	12:45	TW	0.50	6.9	9.0	0.028	1.6	7.5	1.4	7.3	74	71	13	11	11	12	11	11	12	12	13	12			32.8	4217991
14	11:33	AK	0.55	6.8	9.0	0.030	1.6	7.8	1.3	7.2	74	71	10	10	10	10	10	10	10	10	11	11			32.9	4219346
15	10:30	AK	0.52	6.8	9.0	0.029	1.6	7.7	1.3	7.3	74	71	11	10	10	10	10	10	10	10	10	11			32.6	4220654
16	9:50	AK	0.59	6.8	8.5	0.027	1.8	7.8	1.3	7.2	74	71	11	10	10	10	10	10	10	10	12	11			32.7	4221861
17	9:30	Bm	0.55	6.8	7.5	0.030	1.7	7.7	1.5	7.5	74	71	11	10	11	11	11	11	11	11	12	11	X	X	31.5	4223139
18	8:15	AK	0.40	6.8	9.0	0.027	1.7	7.7	1.6	7.4	74	71	11	10	10	11	11	10	10	11	12	11			32.5	4224330
19	9:30	Bm	0.48	6.8	8.5	0.028	1.6	7.9	1.4	7.4	74	71	10	10	11	10	10	10	10	11	12	11			33.3	4225680
20	11:40	TW	0.39	6.8	8.5	0.028	1.7	7.7	1.4	7.4	71	67	11	10	12	11	13	11	11	12	12	12			32.9	4226841
21	7:10	AK	0.45	6.8	9.0	0.027	1.6	7.7	1.2	7.2	74	71	10	10	10	10	10	10	11	11	12	11			33.0	4227725
22	13:30	AK	0.49	6.8	9.0	0.027	1.6	7.7	1.2	7.3	74	71	10	10	10	10	10	10	10	10	12	11			33.6	4229458
23	7:15	AK	0.42	6.8	8.5	0.027	1.6	7.6	1.3	7.3	74	71	10	10	10	10	10	10	10	10	11	11			33.0	4230363
24	7:30	Bm	0.37	6.8	8.5	0.027	1.6	7.7	1.3	7.3	71	71	10	10	11	10	11	10	11	10	11	11	X		32.2	4232233
25	8:30	Bm	0.38	6.8	8.0	0.026	1.6	7.8	1.4	7.3	74	71	10	10	10	10	10	10	11	10	12	11			32.6	4233615
26	9:50	Bm	0.35	6.8	8.5	0.027	1.6	7.9	1.4	7.3	74	71	10	10	11	10	10	10	11	11	12	11			32.5	4235159
27	9:40	TW	0.33	6.8	9.0	0.024	1.7	7.5	1.3	7.2	74	70	13	10	12	11	12	11	12	12	13	12			33.3	4236997
28	10:00	AK	0.41	6.8	9.0	0.027	1.5	7.8	1.3	7.2	74	69	10	10	10	10	10	10	10	10	11	11			31.9	4237751
29	14:00	AK	0.46	6.8	9.0	0.027	1.4	7.8	1.2	7.2	74	71	10	10	10	10	10	10	10	10	11	11			33.1	423944.6
30	7:10	AK	0.35	6.8	8.5	0.027	1.6	7.7	1.4	7.3	74	71	10	10	10	10	10	10	10	10	11	10			32.6	4240382
31	9:30	Bm	0.33	6.8	8.0	0.028	1.6	7.9	1.4	7.5	71	71	11	10	11	11	10	10	11	11	12	11	X		32.3	4241866

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point			Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F -	Clear Water Level - Daily											
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP			Gallons	
1	16:30	AK																							5600	Mix Chl 6gals/12"
2	7:20	AK																							5600	
3	9:35	BM	X		^		X		X		X		^		X		X		X		X				5600	
4	9:00	BM																							5600	
5	9:05	BM																							5600	RAW 6-8 DISTR-7.3
6	11:30	TW																							6000	
7	9:55	AK																							6000	
8	10:25	AK																							5700	
9	8:35	AK																							5600	
10	9:10	BM	X		X		^		X		^		^		X		X		X		X				6000	
11	7:30	BM																							5900	
12	12:30	BM																							5900	RAW-6.8 DISTR-7.4
13	12:45	TW																							6000	
14	11:30	AK																							5600	
15	10:30	AK																							6000	
16	9:50	AK																							5900	
17	9:30	BM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X			5900	
18	8:15	BM																							5900	
19	9:30	BM																							5600	RAW 6.8 DISTR-7.4
20	11:00	TW																							4500	Power outogen pump
21	7:10	AK																							5600	Mix Soda 6gals/12"
22	13:20	AK																							5700	
23	7:15	AK																							6000	
24	9:30	BM	X		X		X		X		X		X		X		X		X		X				5900	
25	9:30	BM																							5900	
26	9:50	BM																							5900	RAW 6.8 DISTR 7.3
27	9:40	TW																							6000	
28	10:00	AK																							5600	
29	14:00	AK																							5700	
30	7:10	AK																							5600	
31	9:30	BM	X		^		X		X		X		X		X		X		X		X				5600	

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete

Note: MIT - Pass (P) or Fail (F)

Note: CIP - X for complete