



IWT UF SERIES
WEEKLY INTEGRITY TESTING
TESTING, AS NEEDED.

Meadow Mountain Water Supply Company

MONTH__ YEAR_2020__

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser	
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out															
	24 Hr	Initials			deg C	<1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi										X	P/F	gpm	Gpd	
1	9:10	AK	0.32	6.7	4.0	0.22	1.6	7.6	1.3	7.2	74	71	12	11	11	12	12	11	12	12	12	12			30.2	4328842	
2	8:25	BM	0.54	6.8	4.0	0.22	1.7	8.3	1.4	7.4	74	71	12	12	12	12	12	12	12	13	12	X		31.2	4330188		
3	15:30	BM	0.32	6.8	6.0	0.24	1.5	7.9	1.4	7.2	74	71	12	12	12	13	13	12	12	12	13	13			32.8	4331997	
4	8:45	BM	0.27	6.8	3.5	0.23	1.5	8.0	1.4	7.3	74	71	12	12	12	13	12	12	12	13	13	13			33.0	4332935	
5	10:05	TW	0.26	6.8	3.5	0.22	1.9	7.5	1.5	7.1	74	71	13	13	13	15	14	12	14	14	15	14			32.7	4334545	
6	9:30	AK	0.33	6.8	4.0	0.22	1.5	7.8	1.4	7.2	74	71	12	12	12	13	12	12	12	12	14	13			32.0	4335937	
7	8:30	AK	0.30	6.8	4.0	0.23	1.6	7.7	1.4	7.2	74	71	12	12	12	13	12	12	12	12	13	13			32.3	4337384	
8	9:00	AK	0.26	6.8	3.5	0.23	1.8	7.6	1.4	7.2	74	71	12	12	12	13	12	12	12	12	13	13			31.1	4338856	
9	8:10	BM	0.30	6.8	4.0	0.24	1.7	8.0	1.5	7.2	74	71	12	12	12	12	12	12	12	12	13	12	X	X	30.8	4340200	
10	11:30	AK	0.33	6.8	3.5	0.23	1.6	7.7	1.4	7.2	74	71	12	11	12	12	12	12	12	12	13	13			32.0	4342206	
11	11:00	AK	0.38	6.8	3.5	0.23	1.6	7.6	1.4	7.2	74	71	12	11	12	12	12	12	12	12	13	12			31.4	4343584	
12	15:50	TW	0.49	6.8	3.5	0.23	1.7	7.6	1.5	7.3	75	71	12	12	13	13	13	12	13	13	14	13			31.2	4345212	
13	9:25	AK	0.36	6.8	3.5	0.23	1.7	7.6	1.4	7.3	74	71	12	12	12	13	12	12	12	12	13	14			31.1	4346355	
14	10:15	AK	0.34	6.8	4.0	0.22	1.7	7.6	1.4	7.3	74	71	13	12	13	13	13	12	13	12	13	13			31.8	4347788	
15	10:30	AK	0.33	6.8	4.0	0.23	1.6	7.5	1.4	7.2	74	71	13	12	12	13	13	13	13	13	14	13			32.1	4349250	
16	8:40	BM	0.32	6.8	5.0	0.23	1.5	8.0	1.4	7.6	74	71	12	12	13	13	12	12	12	13	13	13	X		32.4	4350496	
17	7:10	BM	0.33	6.8	3.5	0.22	1.6	8.4	1.5	7.9	74	71	13	13	13	13	13	12	13	13	14	13			31.7	4351748	
18	8:25	BM	0.28	6.8	3.0	0.23	1.8	8.0	1.6	7.4	75	72	13	13	13	13	13	12	13	13	13	13			30.2	4352838	
19	07:50	TW	0.26	6.8	3.0	0.23	1.6	7.6	1.5	7.4	75	71	13	13	13	13	13	13	13	13	13	13			29.3	4354070	
20	9:50	AK	0.36	6.8	3.0	0.23	1.5	7.8	1.3	7.3	75	71	12	12	12	13	12	12	12	12	13	13			29.5	4355413	
21	10:10	AK	0.33	6.8	3.0	0.23	1.4	7.7	1.2	7.3	75	71	12	12	12	13	12	12	12	12	13	13			30.1	4356757	
22	8:45	AK	0.33	6.8	3.0	0.23	1.6	7.7	1.4	7.3	75	71	12	12	12	13	12	12	12	12	13	12			30.3	4357959	
23	8:40	BM	0.26	6.8	3.5	0.25	1.8	7.9	1.5	7.8	74	71	13	12	13	13	13	12	13	13	13	13	X		31.4	4359185	
24	8:30	BM	0.37	6.8	3.0	0.25	1.6	8.2	1.6	7.4	74	71	13	12	13	13	13	12	13	13	13	13			30.8	4360461	
25	8:55	BM	0.42	6.8	2.5	0.25	1.6	8.1	1.6	7.8	74	71	13	12	13	13	13	13	13	13	14	13			30.7	4361832	
26	12:03	TW	0.30	6.8	2.5	0.24	1.5	7.6	1.4	7.2	74	71	14	13	14	14	14	14	14	14	15	14			32.3	4363383	
27	10:30	AK	0.38	6.8	3.0	0.25	1.6	7.8	1.3	7.4	75	72	13	12	13	14	13	13	13	13	14	13			31.3	4364603	
28	11:15	AK	0.45	6.8	3.0	0.26	1.6	7.8	1.4	7.3	75	72	13	12	13	14	13	13	13	13	14	14			30.9	4366004	
29	15:20	AK	0.32	6.8	3.0	0.25	1.5	7.8	1.3	7.3	74	71	13	12	13	13	13	13	13	13	14	13			30.6	4367570	
30	9:00	BM	0.57	6.8	3.0	0.25	1.5	8.0	1.3	7.6	74	72	13	12	13	13	14	13	13	13	13	13	X	X	30.6	4368365	
31																											

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

MONTH YEAR 2020

[illegible]