



Certificate of Analysis

Meadow Mountain Water Supply Company
PO Box 162
Cust #10757
Allenspark CO
Attn: Andrew Griffiths

Date Received: 5/16/2022
Date Reported: 5/17/2022

Location Name: MMWS-2-Newton

Meadow Mountain Water Supply-2-Newton

Sample Date: 5/16/2022 Sample Time: 10:00 AM

System ID: CO0207504

Sample ID: 220516-0004

Matrix: Water

Analysis	Results	Units	Limit of Quantitation	Method	Invoice
Total Coliform	Absent	P/A	0 P/A	9223	
E. coli	Absent	P/A	0 P/A	9223	
Cl2 Free	0.40	mg/L	0.02 mg/L	SM 4500-CL	

Our Company makes no warranty except that the analysis has been made upon the samples received in accordance with generally accepted testing laboratory principles and practices and by methods approved by the U.S. EPA and State Department of Health. The results of the analysis may not be characteristic of the whole from which the sample was taken.

Results Approved by:

Laboratory/Water Quality Supervisor

Please contact Water Quality Supervisor at 970-577-3624 or via email dcallahan@estes.org if you have any questions regarding the testing above

Sample Notes:



**Town of Estes Park
Water Department
Chain of Custody**

Client/Billing Information:

Company: MEANEW MTN WATER SUPPLY CO

Address: BOX 163, ALLENSPARK CO 80510

Contact: ANDREW GRIFFITHS

Phone: 303-747-2715 e-mail: andrew@mtwsl.net

System Information:

PWSID# 207504

System Address: _____

Contact Person: _____

Phone: _____ e-mail: _____

State Form Information:
State Form Required
Compliance Samples
Submit Forms to State

☒	☒	☒	Yes
☒	☒	☒	Yes
☒	☒	☒	Yes
☐	☐	☐	No
☐	☐	☐	No
☐	☐	☐	No

Water Supply:
Public/Community ☒ Private ☐

Samplers Signature: *A. J. C...*

[illegible]

Relinquished By:	Date:	Time:	Received By:
P. J. Connelly	5/16/22	2:30p	MB 2/16/22 2:40
Relinquished By:	Date:	Time:	Received By:

Notes/Remarks:
R 220516 -0004

Create Coliform CSV File Instructions - Version 8/

1. Enable Macros.
2. Enter sample results starting in the row below the column titles.
3. Press the button.
4. Name the CSV file.
5. Select a folder to save the CSV file to.

Notes:

-OK to change column order, but not column names.

-Only Coliform/E. Coli Results are allowed.

[illegible]