



Certificate of Analysis

Meadow Mountain Water Supply Company
PO Box 162
Account #10575-9090
Allenspark CO
Attn: Andrew Griffiths

Date Received: 11/7/2022
Date Reported: 11/10/2022

Location Name: MMWS-2-Newton

Meadow Mountain Water Supply-2-Newton

Sample Date: 11/7/2022

Sample Time: 10:45 AM

System ID: CO0207504

Sample ID: 221107-0010

Matrix: Water

Analysis	Results	Units	Limit of Quantitation	Method	Invoice
Total Coliform	Absent	P/A	0 P/A	9223	
E.coli	Absent	P/A	0 P/A	9223	
Cl2 Free	0.65	mg/L	0.02 mg/L	SM 4500-CL	


Our Company makes no warranty except that the analysis has been made upon the samples received in accordance with generally accepted testing laboratory principles and practices and by methods approved by the U.S. EPA and State Department of Health. The results of the analysis may not be characteristic of the whole from which the sample was taken.

Results Approved by:

Laboratory/Water Quality Supervisor

Please contact Water Quality Supervisor at 970-577-3624 or via email dcallahan@estes.org if you have any questions regarding the testing above

Sample Notes: RTOR #2



ESTES PARK
COLORADO

System Information		Billing Information (if different):	
PWSID#:	CO 0207504, Meadow Mountain Water Supply Co	Company:	Meadow Mountain Watr Supply Co.
Address:	P.O. Box 162	Address:	P.O. Box 162, Allenspark CO 80510
Contact:	Barry Mauerman	Contact Person:	Rachel Barkworth
Phone:	303-747-0317 e-mail: barry.mauerman@gmail.com	Phone:	303-823-2318 e-mail: rachel@bluegatebooks.com

	Yes	No	
State Form Required	☒	☐	
Compliance Samples	☒	☐	
Submit Forms to State	☒	☐	

Water Supply: ☒ Public/Community ☐ Private

Samplers Signature:

Bay Menu

[illegible]

Relinquished By:	Date:	Time:	Received By:
Bay Mun	11/17/22	12:50	Rob Callahan
Relinquished By:	Date:	Time:	Received By:

Notes/Remarks:

Notice of sample invalidation: samples taken for microbiological determination will be invalidated if: (1) received in the laboratory more than 24 hours after collection, (2) a presence of disinfectant is noticed, (3) evidence of freezing, (4) use of unapproved containers, (5) sample volume < 100 ml, (6) presence of interfering contaminants, (7) sample temperature > 10° C unless collection is within 2 hours of receipt in the laboratory.

Create Coliform CSV File Instructions - Version 8/

1. Enable Macros.
2. Enter sample results starting in the row below the column titles.
3. Press the button.
4. Name the CSV file.
5. Select a folder to save the CSV file to.

Notes:

- OK to change column order, but not column names.
- Only Coliform/E. Coli Results are allowed.

[illegible]