

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out														
	24 Hr	Initials			deg C	<.1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi													
			OPER										TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
1	10:00	MR	0.33	6.8	2.0	0.024	1.3	7.6	1.2	7.1	74	71	13	12	13	13	13	13	14	13	14				32.2	4419345
2	10:50	MR	0.33	6.7	1.5	0.024	1.5	7.6	1.2	7.1	74	71	13	12	13	13	13	13	13	13	14	13			30.8	4421278
3	10:15	MR	0.40	6.8	2.0	0.024	1.3	7.8	1.2	7.1	74	71	13	13	13	13	13	13	13	13	14	14			30.4	4423368
4	9:30	BM	0.39	6.8	2.0	0.024	1.3	7.9	1.2	7.4	74	72	13	13	13	13	13	13	13	13	14	14	X		30.5	4425201
5	10:10	BM	0.31	6.8	2.5	0.024	1.5	7.8	1.4	7.3	74	71	13	13	13	13	13	13	13	13	14	13			32.3	4427119
6	12:10	BM	0.35	6.8	1.5	0.024	1.6	7.9	1.3	7.7	74	71	13	13	13	13	13	13	13	13	14	13			30.3	4429159
7	9:50	MR	0.33	6.8	2.0	0.024	1.4	7.7	1.2	7.3	74	71	13	13	13	14	13	13	13	13	14	14			30.5	4430833
8	10:30	MR	0.34	6.8	2.0	0.024	1.3	7.6	1.2	7.3	74	71	13	13	13	13	13	13	13	13	14	14			31.0	4433544
9	11:10	MR	0.32	6.8	2.0	0.024	1.2	7.6	1.2	7.2	75	72	13	13	13	13	13	13	13	13	14	14			30.3	4435786
10	8:45	MR	0.30	6.8	2.0	0.024	1.3	7.8	1.2	7.2	75	72	13	13	13	13	13	13	13	13	14	13			30.2	4437663
11	9:40	BM	0.50	6.8	2.0	0.024	1.4	8.0	1.3	7.5	75	72	13	13	13	13	13	13	13	13	14	13	X	X	29.8	4440101
12	9:50	BM	0.45	6.8	2.0	0.024	1.6	8.0	1.3	7.3	74	72	13	12	12	13	12	12	13	13	13	13			30.3	4442445
13	9:30	BM	0.35	6.8	2.5	0.024	1.5	7.9	1.3	7.2	74	71	13	13	13	13	13	13	13	13	14	13			32.3	4444756
14	11:45	TW	0.52	6.8	2.5	0.024	1.5	7.7	1.3	7.3	74	71	13	13	13	13	13	13	13	13	13	13			31.8	4447326
15	11:00	MR	0.30	6.8	2.0	0.024	1.5	7.8	1.2	7.2	75	72	13	12	13	13	13	13	13	13	14	13			30.3	4449721
16	10:15	MR	0.33	6.8	2.0	0.024	1.6	7.6	1.3	7.2	75	72	13	12	13	13	13	13	13	13	13	13			30.5	4451988
17	9:00	MR	0.32	6.8	2.0	0.024	1.6	7.6	1.2	7.2	74	71	13	12	13	13	13	13	13	13	13	13			30.0	4454210
18	9:20	BM	0.32	6.8	2.0	0.026	1.5	8.1	1.3	7.7	74	71	13	12	13	13	13	13	13	13	13	13	X		30.5	4456605
19	9:10	BM	0.27	6.8	1.5	0.026	1.5	8.1	1.3	7.4	74	71	13	12	13	13	13	13	13	13	13	13			30.8	4458958
20	9:30	BM	0.34	6.8	1.5	0.026	1.6	8.4	1.3	7.7	74	72	13	12	13	13	13	13	13	13	13	13			30.6	4461317
21	11:55	TW	0.30	6.7	1.5	0.024	1.7	7.6	1.3	7.3	75	71	13	13	13	13	13	13	14	13	14	14			31.0	4463919
22	9:40	MR	0.42	6.8	2.0	0.025	1.4	7.6	1.2	7.2	75	72	13	13	13	13	13	13	13	13	14	13			30.3	4466024
23	10:35	MR	0.52	6.8	1.5	0.025	1.4	7.7	1.3	7.2	75	72	13	12	12	13	13	12	13	13	14	13			30.4	4468600
24	10:05	MR	0.29	6.8	1.5	0.025	1.5	7.7	1.2	7.2	75	72	13	12	13	13	13	13	13	13	14	13			30.3	4470790
25	10:05	AH	0.34	6.8	2.0	0.025	1.6	7.7	1.4	7.4	75	72	13	12	13	13	13	13	13	13	14	13	X		30.4	4473156
26	10:00	BM	0.35	6.8	1.5	0.024	1.5	7.9	1.4	7.3	74	71	13	12	13	13	13	13	13	13	14	14			31.0	4475495
27	9:25	BM	0.40	6.8	1.5	0.025	1.5	8.0	1.3	7.3	75	72	13	12	12	13	13	13	13	13	13	13			32.3	4477785
28	9:15	AH	0.44	6.9	1.5	0.025	1.7	8.1	1.4	7.3	75	72	13	12	13	13	13	13	14	14	14	13			30.2	4480143
29	11:30	MR	0.33	6.8	1.5	0.025	1.6	7.6	1.3	7.2	75	72	13	12	13	13	13	13	13	13	14	13			29.5	4482739
30	9:00	MR	0.31	6.8	1.5	0.025	1.5	7.7	1.2	7.2	75	72	13	12	12	13	13	13	13	13	14	13			29.7	4484833
31	12:45	MR	0.71	6.8	1.5	0.025	1.6	7.8	1.3	7.2	74	71	13	12	13	13	13	12	13	13	14	13			29.5	4487584

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp °F	Clear Well Level - Daily								
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	Gallons		
1	10:00	AK																			12,100		
2	10:50	AK																			12,700		
3	10:15	AK																			12,200		
4	0930	Bm	X		X		X		X		X		X		X		X		X		12,200		
5	1010	Bm																			12,700		
6	1210	Bm																			12,600	RAW-6.8 ASTR 7.7	
7	9:50	AK																			12,600		
8	10:30	AK																			12,300		
9	11:10	AK																			12,400		
10	8:45	AK																			12,600		
11	940	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	12,300		
12	950	Bm																			12,400		
13	930	Bm																			12,300	RAW-6.8 ASTR-7.2	
14	1145	TW																			12,700		
15	11:00	AK																			12,500		
16	10:15	AK																			12,400		
17	9:00	AK																			12,800		
18	920	Bm	X		X		X		X		X		X		X		X		X		11,900		
19	910	Bm																			12,400		
20	930	Bm																			12,500	RAW-6.8 ASTR-7.7	
21	1155	TW																			12,700		
22	9:40	AK																			12,600		
23	10:35	AK																			12,700		
24	10:05	AK																			12,200		
25	10:05	AH	X		X		X		X		X		X		X		X		X		12,100		
26	1020	Bm																			12,400		
27	9:25	Bm																			12,300	RAW 6.8 ASTR-7.3	
28	9:15	AH																			12,400		
29	11:30	AK																			12,300		
30	9:00	AK																			12,400		
31	12:45	AK																			12,200		

RAW-6.8 DISTR 7.7

RAW-6.8 DISTR-7.2

RAW-6.8 DISTR-7.7

RAW 6.8 DISTR-7.3