

742 743

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser	
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out															
		OPER											TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd	
	24 Hr	Initials			deg C	<.1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi														
1	9:20	Bm	0.38	6.8	1.5	.026	1.6	8.3	1.4	7.8	75	72	13	12	13	13	13	13	13	13	14	13	X	X	29.2	4489549	
2	9:40	Bm	0.39	6.8	1.5	.026	1.6	8.2	1.4	7.1	74	71	13	12	13	13	13	13	13	13	14	13			31.1	4491906	
3	8:55	Bm	0.42	6.8	1.5	.025	1.6	8.1	1.4	7.4	75	72	13	12	13	13	13	13	13	13	13	13			29.7	4494131	
4	9:10	AH	0.35	6.8	2.0	.025	1.5	7.8	1.4	7.3	75	72	13	13	13	13	13	13	13	13	14	13			29.4	4496471	
5	8:50	AH	0.38	6.8	1.5	.025	1.6	8.2	1.4	7.3	75	72	13	12	13	13	13	13	13	13	14	13			29.1	4498785	
6	9:15	AH	0.34	6.8	1.5	.025	1.6	7.8	1.4	7.4	75	73	13	12	13	13	13	13	13	13	14	13			30.2	4501211	
7	8:45	Bm	0.52	6.8	2.0	.025	1.6	8.0	1.3	7.5	75	72	13	12	13	13	13	13	13	13	14	13			30.2	4503536	
8	8:40	Bm	0.30	6.8	2.0	.025	1.6	7.9	1.3	7.1	74	71	13	13	14	13	13	13	13	13	14	14	X		31.6	4505872	
9	9:05	Bm	0.29	6.8	1.5	.025	1.6	7.9	1.3	7.2	74	71	13	12	13	13	13	13	13	13	14	13			30.4	4508271	
10	9:40	Bm	0.57	6.8	1.5	.025	1.6	7.8	1.3	7.1	74	72	13	12	13	13	13	13	13	13	13	13			29.8	4510653	
11	9:10	AH	0.55	6.7	2.0	.025	1.6	8.0	1.3	7.5	74	72	13	12	13	13	13	13	13	13	14	14			29.4	4512498	
12	11:40	AH	0.63	6.6	2.0	.025	1.6	8.1	1.3	7.3	74	72	14	13	14	13	13	13	13	13	14	14			31.9	4515588	
13	10:00	AH	0.43	6.7	2.0	.025	1.6	8.3	1.3	7.3	74	72	13	13	13	13	13	13	13	13	14	14			31.7	4517738	
14	9:00	Bm	0.46	6.8	1.5	.025	1.6	7.9	1.4	7.3	74	72	13	12	13	13	13	13	13	13	13	13			29.8	4519942	
15	9:10	Bm	0.51	6.8	1.5	.026	1.6	8.0	1.4	7.4	74	71	13	13	13	13	13	13	13	13	14	13	X		30.2	4522218	
16	9:10	Bm	0.39	6.8	1.5	.025	1.6	8.0	1.3	7.3	74	71	13	12	13	13	13	13	13	13	4	13			30.2	4524497	
17	9:10	Bm	0.29	6.8	1.5	.025	1.6	8.0	1.3	7.3	74	71	13	12	13	13	13	13	13	13	14	14			31.3	4526806	
18	8:20	AH	0.45	6.7	1.5	.025	1.6	8.1	1.3	7.4	74	72	13	12	13	13	13	13	13	13	14	13			30.4	4529031	
19	7:45	AH	0.35	6.7	1.5	.025	1.6	8.3	1.3	7.5	74	72	13	12	13	13	13	13	13	13	14	14			30.5	4531285	
20	8:45	AH	0.41	6.7	1.5	.026	1.6	8.4	1.3	7.8	75	73	13	13	13	13	13	13	13	13	14	14			30.1	4533700	
21	9:45	Bm	0.44	6.8	2.5	.026	1.5	8.0	1.4	7.2	74	72	13	12	13	13	13	13	13	13	14	13			30.3	4536144	
22	9:10	Bm	0.36	6.8	1.5	.025	1.6	8.0	1.2	7.2	74	72	13	12	13	13	13	13	13	13	14	13	X	X	29.5	4538410	
23	10:20	Bm	0.30	6.8	1.5	.026	1.8	8.1	1.7	7.5	74	72	13	12	13	13	13	13	13	13	13	13			30.3	4540865	
24	9:20	Bm	0.31	6.8	1.5	.025	1.5	7.8	1.4	7.2	74	71	14	13	14	14	13	14	14	14	14	14			32.2	4543076	
25	8:00	AH	0.35	6.7	1.0	.025	1.6	8.0	1.2	7.5	74	72	14	12	13	13	13	13	13	13	14	13			30.3	4545242	
26	8:20	AH	0.33	6.5	1.0	.025	1.6	7.9	1.4	7.4	74	72	14	12	13	13	14	13	14	13	14	14			31.9	4547642	
27	8:30	AH	0.57	6.6	1.5	.025	1.6	8.0	1.4	7.7	74	72	13	12	13	13	13	13	14	13	14	14			32.1	4549967	
28	9:15	Bm	0.39	6.8	1.5	.025	1.6	8.0	1.3	7.2	74	72	13	13	13	13	13	13	13	13	13	13			30.4	4552411	
29																											
30																											
31																											

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

X

X

MONTH 02 YEAR ~~2020~~ 2022

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F -	Clear Vent Level - Daily										
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	Gallons		
1	9:20	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	12,300		
2	9:40	Bm																					12,300		
3	8:55	Bm																					12,100	RAW-6.5 DISTR-7.4	
4	9:10	AH																					12,100	RAW=6.8 Dist-7.3	
5	8:30	AH																					12,200	RAW=6.8 Dist-7.3	
6	9:15	AH																					12,100	RAW=6.8 Dist-7.4	
7	8:45	Bm																					12,600		
8	8:40	Bm	X		X		X		X		X		X		X		X		X		X		12,300		
9	9:15	Bm																					12,500		
10	9:40	Bm																					12,300	RAW-6.8 DISTR-7.4	
11	9:10	AH																					12,000		
12	11:40	AH																					12,200		
13	10:00	AH																					12,200		
14	9:00	Bm																					12,200		
15	9:15	Bm	X		X		X		X		X		X		X		X		X		X		12,500		
16	9:10	Bm																					12,300		
17	9:10	Bm																					12,300	RAW-6.8 DISTR-7.3	
18	8:20	AH																					12,000		
19	7:45	AH																					12,300		
20	8:45	AH																					12,200		
21	9:45	Bm																					12,300	CHL CHECK-PASS CHL CHX	
22	9:30	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	12,300	CHL CHX	
23	10:20	Bm																					12,600		
24	9:20	Bm																					11,900	RAW-6.8 DISTR-7.4	
25	8:00	AH																					11,800		
26	8:20	AH																					12,200		
27	8:30	AH																					12,000		
28	9:30	Bm																					12,300		
29																									
30																									
31																									