

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	Flow	Totaliser
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out														
		OPER											TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	gpm	Gpd
													Baseline TMP was 10 psi													
1	9:30	Bm	0.32	6.8	2.0	0.25	1.6	7.9	1.6	7.2	74	72	14	13	13	13	13	13	13	13	14	14			30.8	4554742
2	9:10	Bm	0.39	6.8	1.5	0.27	1.6	7.9	1.4	7.3	74	72	14	13	13	13	13	13	14	14	14	14			30.6	4557011
3	10:00	Bm	0.47	6.9	1.5	0.27	1.6	8.1	1.4	7.2	74	71	13	13	13	13	13	13	13	14	13			31.1	4557879	
4	8:30	AH	0.31	6.7	2.0	0.25	1.6	8.1	1.5	7.5	74	71	13	13	14	14	13	13	14	14	14	14			31.4	4561529
5	8:15	AH	0.35	6.8	1.5	0.26	1.6	8.0	1.4	7.8	74	71	13	12	13	13	13	13	13	13	14	13			30.5	4563805
6	8:15	AH	0.36	6.8	1.0	0.26	1.6	8.1	1.4	7.7	74	72	13	13	13	13	13	13	13	13	14	14			30.4	4566194
7	9:15	Bm	0.49	6.8	1.0	0.25	1.6	8.0	1.4	7.3	74	71	13	13	13	13	13	13	13	13	14	13			30.1	4568635
8	9:20	Bm	0.29	6.8	1.5	0.25	1.6	8.0	1.4	7.2	74	72	13	13	13	13	13	13	13	13	14	13	X		30.7	4570963
9	9:45	Bm	0.32	6.8	1.0	0.27	1.6	8.0	1.4	7.2	74	72	13	13	13	13	13	13	13	13	14	13			31.5	457273
10	8:20	Bm	0.32	6.8	1.0	0.26	1.7	7.9	1.5	7.3	74	71	13	12	13	13	13	13	13	13	14	13			30.1	4575497
11	8:25	AH	0.42	6.9	1.0	0.27	1.6	8.1	1.4	7.4	74	71	14	13	13	13	13	13	13	13	14	14			30.6	4577841
12	8:20	AH	0.37	6.7	2.0	0.27	1.6	8.1	1.4	7.7	74	71	14	13	13	14	13	13	13	13	14	14			30.1	4580091
13	9:15	AH	0.56	6.8	1.5	0.28	1.7	8.1	1.3	7.5	74	72	13	13	13	13	13	13	13	13	14	13			30.0	4582399
14	8:00	Bm	0.31	6.8	1.5	0.25	1.6	7.9	1.3	7.2	74	72	13	12	13	13	13	13	13	13	14	13			30.1	4584593
15	9:40	Bm	0.35	6.8	1.5	0.26	1.6	8.0	1.3	7.0	74	71	13	13	13	14	13	13	13	13	14	14	X	X	31.5	4587053
16	9:25	Bm	0.30	6.8	1.5	0.27	1.6	8.2	1.4	7.5	74	71	13	13	13	13	13	13	13	13	14	14			31.7	4589299
17	11:00	Bm	0.40	6.8	1.5	0.26	1.6	8.1	1.4	7.2	74	71	13	13	13	13	13	13	13	13	14	13			32.3	4591739
18	9:10	AH	0.44	6.8	1.5	0.29	1.6	8.0	1.4	7.6	74	71	13	13	13	14	13	13	13	13	14	14			31.3	4593886
19	8:15	AH	0.36	6.7	1.5	0.26	1.6	8.1	1.4	7.4	74	71	13	13	13	13	13	13	13	13	14	14			31.1	4596076
20	8:35	AH	0.64	6.7	1.5	0.25	1.7	8.1	1.3	7.6	73	71	13	13	13	13	13	13	13	13	14	13			31.1	4598466
21	9:50	Bm	0.38	6.7	2.0	0.25	1.6	8.0	1.4	7.2	74	71	13	13	13	13	13	13	13	13	14	14			32.4	4600922
22	8:40	Bm	0.43	6.7	1.5	0.31	1.6	8.0	1.3	7.4	74	71	13	13	13	13	13	13	13	13	14	13	X		30.3	4603097
23	8:50	Bm	0.32	6.7	2.0	0.31	1.6	8.1	1.4	7.3	74	71	13	13	13	13	13	13	13	13	14	13			30.9	4605503
24	8:40	Bm	0.33	6.7	1.5	0.26	1.6	8.1	1.3	7.3	74	71	13	12	13	13	13	13	13	13	14	13			29.5	4607802
25	8:15	AH	0.34	6.6	2.0	0.26	1.6	8.0	1.5	7.4	74	71	13	12	12	13	13	13	13	13	14	13			30.4	4610079
26	7:55	AH	0.31	6.6	2.0	0.27	1.6	8.1	1.4	7.6	74	71	12	12	13	13	13	13	13	13	14	13			30.9	4612369
27	8:25	AH	0.40	6.7	2.0	0.26	1.6	8.5	1.4	7.9	74	71	12	12	13	13	13	13	13	13	14	13			30.0	4614746
28	9:10	Bm	0.29	6.7	2.0	0.26	1.7	8.0	1.4	7.6	74	71	12	12	13	13	13	13	13	13	13	13			29.6	4617162
29	9:30	Bm	1.32	6.8	2.0	0.26	1.6	8.1	1.3	7.5	74	71	13	13	13	13	13	13	13	13	14	13	X		30.1	4619609
30	9:20	Bm	0.39	6.8	2.0	0.26	1.6	8.2	1.3	7.4	74	71	13	13	13	14	13	13	13	13	14	14			31.6	4621836
31	9:05	Bm	0.44	6.8	1.5	0.26	1.6	8.2	1.3	7.3	74	71	13	13	13	13	13	13	13	13	14	13			31.1	4624082

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

CHL 780
CHECK

X P

X P

X P

X P

X P

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F -	Clear well Level - Daily	Gallons							
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP			
1	9:30	Bm	X		X		X		X		X		X		X		X		X			12,400	
2	9:05	Bm																				12,200	
3	10:00	Bm																				12,300	
4	8:30	AH																				12,200	
5	8:15	AH																				12,500	
6	8:15	AH																				12,000	
7	9:15	Bm																				12,000	
8	9:30	Bm	X		X		X		X		X		X		X		X		X			12,600	
9	9:45	Bm																				12,300	
10	8:20	Bm																				12,400	
11	8:25	AH																				12,300	
12	8:20	AH																				12,600	
13	9:15	AH																				12,400	
14	8:00	Bm																				12,400	
15	9:40	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		12,100	
16	9:25	Bm																				12,400	
17	11:00	Bm																				11,800	
18	9:10	AH																				12,000	
19	8:15	AH																				12,300	
20	8:35	AH																				11,900	
21	9:50	Bm																				12,200	
22	8:40	Bm	X		X		X		X		X		X		X		X		X			12,200	
23	8:50	Bm																				12,300	
24	8:40	Bm																				12,300	
25	8:15	AH																				12,200	
26	7:55	AH																				12,200	
27	8:25	AH																				12,000	
28	9:10	Bm																				12,300	
29	9:30	Bm	X		X		X		X		X		X		X		X		X			12,000	
30	9:20	Bm																				12,300	
31	9:05	Bm																				12,300	