

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	CHL	Flow	Totaliser
		OPER	NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	CAL	gpm	Gpd
	24 Hr	Initials			deg C	<1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi														
1	8:15	AH	1.01	6.6	2.5	0.027	1.43	8.3	1.33	7.8	74	71	13	13	13	13	13	13	13	13	14	13				31.1	4684860
2	10:20	AK	1.19	6.8	2.5	0.027	1.99	8.1	1.27	7.7	74	71	13	12	12	13	12	12	12	13	13	13				29.7	4686637
3	9:50	AK	1.27	6.5	2.5	0.029	2.39	8.1	1.36	7.6	74	71	14	13	13	14	14	14	14	14	14	14		X		32.7	4688193
4	9:00	AK	1.56	6.7	2.5	0.027	1.90	8.3	1.25	7.6	74	71	13	13	13	14	13	13	13	13	14	14				32.2	4689777
5	8:50	AK	1.42	6.8	3.0	0.027	2.35	8.3	1.43	7.6	74	71	13	13	13	13	13	13	13	13	14	14		XP		30.7	4691370
6	9:05	AH	1.18	6.6	3.5	0.028	1.85	8.2	1.35	7.6	74	71	13	13	13	14	13	13	13	13	14	14				31.7	4693046
7	7:50	AH	1.83	6.8	3.5	0.029	2.12	8.3	1.24	7.6	74	71	13	13	13	14	13	13	13	13	14	13				30.4	4694585
8	8:50	AH	4.74	6.8	3.5	0.030	1.90	8.1	1.24	7.6	72	69	13	13	13	14	13	13	13	13	14	14				31.1	4696309
9	9:00	AK	3.39	6.8	3.5	0.029	2.20	8.1	1.20	7.5	72	69	13	13	13	13	13	13	13	13	14	14				31.5	4697971
10	9:10	Bm	5.06	6.8	3.5	0.029	2.49	7.8	1.21	7.4	74	71	14	13	14	14	13	14	14	14	14	14		X		32.7	4699594
11	7:40	Bm	2.70	6.8	4.0	0.029	2.54	8.3	1.55	7.6	74	71	13	13	13	14	13	13	13	13	14	13				31.6	4701043
12	7:00	Bm	2.55	6.8	4.0	0.030	2.89	8.4	1.37	7.7	74	71	14	13	14	14	14	14	14	14	14	14		XP		32.0	4702627
13	7:40	AH	2.36	6.9	4.0	0.029	2.35	8.4	1.46	7.9	74	71	13	13	13	13	13	13	14	14	14	14				31.1	4704333
14	8:00	AH	2.37	6.9	4.5	0.029	2.42	8.3	1.46	7.9	74	71	14	13	14	14	14	14	14	13	14	14				32.5	4706005
15	8:30	AH	1.87	6.8	4.0	0.029	2.61	8.3	1.69	7.9	74	71	13	13	13	13	13	13	13	13	14	13				32.4	4707458
16	10:20	AK	1.80	6.8	4.0	0.028	2.73	8.4	1.25	7.7	73	69	12	12	12	13	12	12	12	12	13	13				27.7	4709013
17	8:30	Bm	2.08	6.8	4.5	0.029	2.68	8.5	1.52	7.9	74	70	13	13	13	13	13	13	13	13	14	13	X	X		30.8	470180
18	7:35	Bm	3.96	6.7	4.5	0.031	2.31	8.5	1.34	7.7	74	71	14	13	13	14	14	14	14	14	15	14				32.4	4711583
19	8:10	Bm	2.53	6.8	4.5	0.031	2.65	8.5	1.31	8.1	74	71	13	13	13	13	13	13	13	13	14	13		XP		31.6	4713073
20	9:00	AK	2.91	6.8	4.0	0.032	3.05	8.5	1.02	7.7	72	69	13	13	13	14	13	13	13	13	14	14				32.5	4714463
21	8:30	AH	3.89	6.9	3.5	0.032	2.41	8.4	1.27	7.9	74	71	13	13	13	14	13	13	13	13	14	14				31.9	4715808
22	8:50	AK	1.53	6.9	4.0	0.030	2.46	8.6	1.75	7.8	73	70	13	13	13	13	13	13	13	13	14	14				32.2	4717234
23	9:15	AK	1.17	6.8	4.0	0.029	2.56	8.6	1.86	7.9	74	70	13	13	13	14	13	13	13	13	14	14				32.0	4718769
24	9:10	Bm	2.40	6.8	4.5	0.029	2.88	8.5	1.64	7.9	75	72	12	12	12	13	12	12	12	12	13	13		X		29.7	4720129
25	9:20	Bm	0.67	6.9	4.0	0.029	2.82	8.6	1.84	8.0	74	71	12	12	12	12	12	12	12	12	13	12				29.0	4721440
26	8:35	Bm	0.85	6.8	4.5	0.029	2.68	8.5	1.84	7.9	74	71	12	12	12	12	12	12	12	12	13	12		XP		30.3	4722743
27	8:30	AH	0.84	6.9	5.0	0.031	2.52	8.2	1.55	7.9	74	70	12	12	12	12	12	12	12	12	13	12				30.2	4724119
28	9:00	AH	1.10	6.8	5.0	0.030	2.63	8.6	1.31	8.1	74	70	13	13	12	13	13	12	13	12	13	13				29.3	4725534
29	11:15	AK	0.99	6.8	5.0	0.031	2.79	8.5	1.54	7.8	73	69	12	12	12	13	12	13	12	12	13	13				30.9	4727226
30	10:30	AK	1.45	6.8	5.0	0.031	2.88		1.58	7.7	68	65	13	13	13	14	13	13	14	13	14	14				31.0	4728605
31	10:20	Bm	3.48	6.9	5.0	0.030	2.84	8.6	1.67	7.8	74	71	13	13	13	13	13	13	13	13	14	13		X		29.0	4729991

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

IWT UF SERIES
WEEKLY INTEGRITY TESTING
TESTING, AS NEEDED.

Meadow Mountain Water Supply Company

MONTH 08 YEAR 2020 2022

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp - °F -	Clear well Level - Daily						
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	Gallons		
1	8:15	AH																	12,200		
2	10:20	MR																	11,800		
3	9:50	MR	X		X		X		X		X		X		X		X		11,700		
4	9:00	MR																	11,800		
5	8:50	MR																	12,100	RAW 6-8 DIST-7-6	
6	9:05	AH																	12,100		
7	7:50	AH																	12,000		
8	8:50	AH																	12,000		
9	9:00	MR																	11,400		
10	9:10	BM	X		X		X		X		X		X		X		X		12,100		
11	7:40	BM																	12,200		
12	7:00	BM																	11,800	RAW-6-8 DIST-7-7	
13	7:40	AH																	11,800		
14	8:30	AH																	12,100		
15	8:30	AH																	12,100		
16	10:20	MR																	12,000		
17	8:30	BM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	12,100		
18	7:35	BM																	11,900		
19	8:10	BM																	12,000	RAW-6-8 DIST-8-1	
20	9:00	MR																	12,000		
21	8:20	AH																	11,900		
22	8:50	MR																	12,000		
23	9:15	MR																	12,000		
24	9:10	BM	X		X		X		X		X		X		X		X		12,900		
25	9:20	BM																	13,000		
26	8:35	BM																	12,500	RAW-6-8 DIST-7-9	
27	8:30	AH																	12,100		
28	9:00	AH																	12,200		
29	11:15	MR																	12,900		
30	10:30	MR																	13,000		
31	10:20	BM	X		X		X		X		X		X		X		X		12,100		