

DAY	TIME	CERT	Raw		Finished		Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	CHL	Flow	Totaliser	
			OPER	NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	X	P/F	CAL	gpm	Gpd						
				Initials		deg C	<.1	mg/L	>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi													
24 Hr																										
1	9:55	BM	0.93	7.0	6.5	0.033	2.54	7.7	1.68	7.5	75	72	12	12	12	13	12	12	12	12	12	13	12	28.9	4731275	
2	9:10	BM	1.07	6.9	4.5	0.031	2.56	7.8	1.56	7.3	75	72	13	13	12	13	13	13	13	13	13	13	13	Xp	28.2 4732666	
3	9:15	AH	0.57	6.8	5.5	0.031	2.45	7.7	1.51	7.5	75	72	13	12	12	13	13	13	12	13	13	13	13	30.4	4734045	
4	8:10	AH	0.55	6.9	5.0	0.029	2.83	7.7	1.21	7.3	74	70	13	13	12	13	13	13	13	13	13	13	13	30.1	4735336	
5	7:40	MR	0.84	6.9	5.0	0.031	3.11	7.8	1.24	7.3	74	71	12	12	12	12	12	12	12	12	12	12	12	27.7	4736857	
6	7:45	MR	0.63	6.8	5.0	0.030	3.28	8.1	1.29	7.6	74	71	12	12	12	12	12	12	12	12	12	12	12	28.5	4738436	
7	7:25	BM	0.55	6.5	5.0	0.030	3.12	7.9	1.21	7.4	73	70	12	12	12	13	12	12	12	12	12	13	12	X X	29.7 4739863	
8	7:55	BM	0.53	6.5	5.5	0.037	3.08	8.3	1.22	7.2	73	69	12	12	12	12	12	12	12	12	12	12	12	28.7	4741338	
9	9:15	BM	0.88	6.6	5.5	0.038	3.91	8.1	1.35	7.6	74	70	13	12	13	13	13	13	13	13	13	13	13	Xp	30.5 4743012	
10	8:55	AH	0.48	6.6	5.5	0.035	3.96	7.9	1.29	7.6	74	71	13	12	12	12	12	12	12	13	13	13	13	30.9	4744628	
11	8:30	AH	0.79	6.5	6.0	0.032	4.46	7.9	1.72	7.4	66	63	12	12	12	12	12	12	12	12	13	12	12	29.2	4746060	
12	10:00	MR	0.50	6.6	6.0	0.033	4.45	8.1	1.63	7.4	74	71	12	12	12	12	12	12	12	12	12	12	12	29.4	47A7831	
13	7:00	MR	0.53	6.5	6.0	0.033	4.24	8.0	1.58	7.4	74	71	12	12	12	12	12	12	12	12	13	13	13	30.0	4749194	
14	14:45	BM	0.43	6.7	6.5	0.032	4.26	8.1	2.09	7.4	74	71	12	12	12	13	12	12	13	12	13	12	12	X	29.3 4751328	
15	9:25	BM	0.36	6.8	6.5	0.035	3.63	8.3	1.91	7.5	74	71	13	13	13	13	12	13	12	14	13	13	13	31.5 4752395		
16	8:40	PM	0.47	6.8	6.5	0.031	3.78	7.7	1.81	7.5	74	70	13	12	12	13	13	13	13	13	14	13	13	Xp	32.5 4753929	
17	7:40	AH	0.31	6.5	7.0	0.031	3.63	7.7	1.43	7.4	74	71	12	12	12	12	12	12	12	14	13	13	13	31.3	4755645	
18	8:35	AH	0.38	6.6	7.5	0.032	3.73	7.9	1.72	7.5	74	70	12	12	12	12	12	12	12	12	13	12	12	30.2	4757282	
19	10:15	MR	0.61	6.6	6.5	0.030	4.12	8.1	1.61	7.4	74	71	12	12	12	12	12	12	12	12	13	12	12	30.3	4759018	
20	7:35	MR	0.54	6.5	6.5	0.030	3.72	8.0	2.21	7.5	74	70	12	12	12	13	12	12	12	13	13	13	13	31.5 4760415		
21	8:25	BM	0.33	6.6	6.5	0.029	3.49	8.1	1.93	7.4	75	72	12	12	12	12	12	12	12	13	12	13	13	30.1	4761857	
22	8:45	AH	0.58	6.6	6.5	0.030	2.93	7.9	1.88	7.7	74	71	12	12	12	12	12	12	12	14	13	13	13	31.7	4763113	
23	8:40	AH	0.47	6.6	7.0	0.033	3.33	7.9	1.72	7.7	73	70	12	12	12	12	12	12	12	13	12	12	12	Xp	29.8 4764618	
24	9:15	AH	0.37	6.6	7.0	0.030	3.13	7.9	1.79	7.4	74	70	12	12	12	12	12	12	12	13	13	13	13	31.1	4766018	
25	9:15	AH	0.38	6.6	7.5	0.029	2.75	7.9	1.72	7.7	74	70	12	12	12	12	12	12	12	14	13	13	13	31.9	4767433	
26	10:40	MR	0.51	6.7	7.0	0.028	2.91	8.1	1.81	7.6	73	70	12	12	12	12	12	12	12	13	13	13	13	31.5	4768930	
27	8:20	MR	0.41	6.6	7.0	0.025	3.11	8.1	2.04	7.7	74	70	12	12	12	12	12	12	12	13	13	13	13	32.6	4770135	
28	1:55	BM	0.35	6.6	7.5	0.025	2.54	8.3	2.12	7.7	74	71	12	12	12	13	12	12	13	13	13	13	13	X	30.0 4772015	
29	8:05	AH	0.67	6.6	8.0	0.028	2.52	8.0	1.90	7.8	74	71	12	12	12	12	12	12	12	14	13	13	13	31.3	4772403	
30	9:35	BM	0.35	6.7	7.0	0.025	2.34	8.2	1.89	7.6	74	71	12	12	12	12	12	12	12	12	13	12	12	Xp	31.4 4774258	
31																										

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

**IWT UF SERIES
WEEKLY INTEGRITY TESTING
TESTING, AS NEEDED.**

Meadow Mountain Water Supply Company

MONTH 06 YEAR 2020-2022