

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	CHL	Flow	Totaliser
		OPER	NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	CAL	gpm	Gpd
	24 Hr	Initials			deg C	<1	mg/L		>1.2mg/L	>7.3	PSI	PSI			Baseline TMP was 10 psi												
1	6:50	AH	0.38	6.6	8.0	0.025	2.32	7.9	1.72	7.7	74	71	13	12	12	12	12	12	12	12	14	13				31.7	4775350
2	8:50	AH	1.03	6.7	7.0	0.025	2.29	7.8	1.54	7.6	75	72	12	12	12	12	12	12	12	13	14	14				30.4	4776869
3	10:00	AK	0.37	6.6	7.0	0.026	2.68	8.1	1.41	7.5	75	71	12	12	12	12	12	12	12	12	13	12				31.7	4778403
4	6:50	AK	0.36	6.8	7.0	0.027	2.34	8.1	1.59	7.4	74	71	12	12	12	12	12	12	12	12	13	12				31.5	4779615
5	9:10	BM	0.32	6.6	7.5	0.023	2.48	8.0	1.71	7.5	74	71	13	12	12	12	12	12	12	12	13	12	X			31.4	4781185
6	8:55	BM	0.33	6.7	7.0	0.026	1.98	8.2	1.31	7.3	74	71	12	12	12	12	12	12	12	12	13	12				32.6	4782563
7	10:15	BM	0.38	6.7	7.5	0.024	2.02	8.3	1.37	7.7	74	71	12	12	12	12	12	12	12	12	13	13		Xp		32.4	4784018
8	8:25	AH	0.34	6.7	7.0	0.028	1.94	8.2	1.26	7.7	74	68	12	12	12	12	12	12	12	12	13	13				31.1	4785289
9	8:00	AH	0.39	6.7	8.0	0.025	2.20	7.9	1.34	7.6	75	72	12	12	12	12	12	12	12	12	13	12				31.8	4786704
10	9:05	AK	0.34	6.7	7.5	0.024	2.04	8.0	1.23	7.5	75	71	12	12	12	12	12	12	12	12	12	12				30.4	4788260
11	7:30	AK	0.33	6.8	7.5	0.023	2.14	8.1	1.48	7.6	75	72	12	12	12	12	12	12	12	12	12	12				29.9	4789524
12	9:35	BM	0.30	6.9	7.5	0.027	2.16	7.9	1.34	7.6	74	72	12	12	12	12	12	12	12	12	12	12	X	X		28.8	4791071
13	8:5	BM	0.31	6.7	6.5	0.029	1.89	8.3	1.57	7.6	74	71	12	12	12	12	12	12	12	12	13	12				31.5	4792527
14	8:45	BM	0.28	6.7	8.0	0.024	2.03	8.1	1.31	7.5	74	71	12	12	12	12	12	12	12	12	12	12			Xp	31.7	4793956
15	7:50	AH	0.35	6.8	8.0	0.025	1.94	8.1	1.36	7.8	75	72	12	12	12	12	12	12	12	12	12	12				30.0	4795298
16	7:45	AH	0.34	6.8	8.0	0.025	2.04	7.8	1.33	7.4	75	72	12	12	12	12	12	12	12	12	13	13				30.6	4796759
17	9:35	AK	0.28	6.8	8.0	0.024	2.00	8.1	1.25	7.5	75	72	12	12	12	12	12	11	11	12	12	12				29.6	4798411
18	7:15	AK	0.32	6.9	7.5	0.024	1.78	8.2	1.29	7.7	74	71	12	12	12	12	12	12	12	12	12	12				32.1	4799517
19	8:15	BM	0.28	6.8	8.5	0.023	1.91	8.2	1.38	7.6	74	71	12	12	12	12	12	12	12	12	12	12		X		31.3	4800798
20	7:40	BM	0.34	6.7	8.5	0.025	1.83	8.3	1.34	7.5	74	71	12	12	12	12	12	12	12	12	13	13				31.7	4802038
21	6:15	BM	0.30	6.7	8.5	0.025	2.07	8.2	1.32	7.6	74	71	13	12	12	12	12	12	12	13	13	13			Xp	31.1	4803716
22	7:50	AH	0.24	6.7	8.0	0.024	1.46	8.1	1.36	7.5	74	71	12	12	12	12	12	12	12	12	13	13				31.2	4805465
23	9:00	AH	0.28	6.7	8.0	0.023	1.99	8.1	1.43	7.6	74	71	12	12	12	12	12	12	12	12	13	13				30.5	4807290
24	10:00	AK	0.47	6.7	8.5	0.024	2.20	8.2	1.20	7.6	74	71	12	12	12	12	12	12	12	12	13	12				30.8	4809325
25	7:40	AK	0.36	6.8	8.0	0.022	2.39	8.1	1.32	7.5	74	71	12	12	12	12	12	12	12	12	13	12				31.4	4810731
26	9:00	BM	0.26	6.7	7.5	0.024	2.21	7.9	1.64	7.5	74	71	12	12	12	12	12	12	12	12	13	12		X		31.4	4812627
27	8:00	BM	0.30	6.8	8.0	0.024	2.28	8.0	1.80	7.6	74	71	12	12	12	12	12	12	12	12	13	12			Xp	30.5	4814769
28	14:10	AK	0.48	6.8	8.0	0.024	2.30	8.0	1.60	7.5	74	71	12	12	12	12	12	12	12	12	14	12				32.1	4817281
29	8:25	AH	0.30	6.9	8.0	0.024	2.24	7.9	1.67	7.6	74	68	12	12	12	12	12	12	12	12	14	13				31.5	4818055
30	8:40	AH	0.33	6.8	8.5	0.028	2.05	7.9	1.68	7.4	74	71	12	12	12	12	12	12	12	12	14	12				30.5	4819716
31	9:00	AK	0.32	6.8	8.5	0.022	2.36	8.1	1.62	7.5	74	71	12	12	12	12	12	12	12	12	13	12				29.7	4821594

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

MONTH 07 YEAR 2020 2022

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point		Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp °F -	Gallons Level - Daily								
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP			
1	6:50	AH																			12,600		
2	8:50	AH																			12,700		
3	10:00	Mx																			12,300		
4	6:50	Mx																			12,400		
5	9:10	Bm	X		X		X		X		X		X		X		X		X		12,700		
6	8:55	Bm																			11,900		
7	10:15	Bm																			12,800	RAW-6.7 DISTR-7.7	
8	8:25	AH																			12,600		
9	8:00	AH																			12,300		
10	9:05	Mx																			12,800		
11	7:30	Mx																			12,800		
12	9:05	Bm	X		X		X		X		X		X		X		X		X		13,200		
13	8:05	Bm																			12,700		
14	8:45	Bm																			12,800	RAW-6.7 DISTR-7.5	
15	7:50	AH																			11,800		
16	7:45	AH																			12,200		
17	9:35	Mx																			12,600		
18	7:15	AH																			12,800		
19	8:15	Bm	X		X		X		X		X		X		X		X		X		12,900		
20	7:40	Bm																			12,200		
21	8:15	Bm																			12,200	RAW-6.7 DISTR-7.6	
22	7:50	AH																			11,900		
23	9:00	AH																			12,300		
24	10:00	Mx																			12,200		
25	7:40	Mx																			12,900		
26	9:00	Bm	X		X		X		X		X		X		X		X		X		12,400		
27	8:00	Bm																			12,500		
28	14:10	Mx																			12,800		
29	8:25	AH																			12,600		
30	8:40	AH																			12,200		
31	9:00	Mx																			12,700		