

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	CHL	Flow	Totaliser			
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out																		
		OPER	NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	CAL	gpm	Gpd			
	24 Hr	Initials			deg C	<1	mg/L	>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi																		
1	7:55	AK	0.39	6.9	8.5	0.023	2.12	8.1	1.63	7.6	74	71	12	12	12	12	12	12	12	12	12				30.1	4823068				
2	9:15	Bm	0.32	6.8	8.5	0.024	1.69	7.9	1.54	7.5	74	71	12	12	12	12	12	12	12	12	12	X	X		30.4	4824874				
3	8:50	Bm	0.36	6.7	8.5	0.026	1.63	8.2	1.52	7.7	74	71	12	11	11	12	12	12	11	11	13				32.1	4826466				
4	10:3	Bm	0.34	6.7	8.5	0.024	1.80	8.1	1.28	7.6	74	71	12	12	12	12	12	12	12	13	12			Xp	33.0	4828220				
5	8:40	AH	0.45	6.8	9.0	0.025	1.81	7.9	1.21	7.7	74	71	12	12	12	12	12	12	12	13	13				32.5	4829785				
6	8:45	AH	0.84	6.9	9.0	0.022	1.99	8.0	1.39	7.8	74	71	12	12	12	12	12	12	12	12	12				31.7	4831486				
7	8:45	AK	0.70	6.7	9.0	0.024	2.00	8.2	1.24	7.6	74	71	12	12	12	12	12	12	12	12	12				31.0	4833257				
8	7:40	AK	0.63	6.9	9.0	0.022	1.92	8.2	1.43	7.7	74	71	12	12	12	12	12	12	12	12	12				30.9	4834734				
9	8:15	Bm	0.39	6.8	9.0	0.022	2.08	8.2	1.37	7.8	74	68	12	12	12	12	12	12	12	13	12		X		32.4	4836582				
10	7:50	Bm	0.41	6.8	8.5	0.024	1.99	8.2	1.53	7.7	74	71	12	11	12	12	12	12	12	13	12				31.9	4838446				
11	8:5	Bm	0.38	6.7	9.0	0.024	2.12	8.2	1.40	7.7	74	71	12	12	12	12	12	12	12	12	12			Xp	30.7	4840131				
12	7:40	AH	0.41	6.8	9.0	0.022	1.99	8.2	1.53	7.7	74	71	12	12	12	12	12	12	12	12	12				30.0	4841756				
13	7:30	AH	0.31	6.7	9.0	0.023	1.98	8.1	1.54	7.7	74	71	12	12	12	12	12	12	12	12	12				30.6	4843699				
14	9:15	AK	0.33	6.7	9.0	0.025	1.94	8.0	1.25	7.6	73	70	12	12	12	12	12	12	12	12	12				31.0	4845696				
15	7:45	AK	0.41	6.8	9.0	0.024	2.11	8.2	1.31	7.7	74	71	12	12	12	12	12	12	12	12	13	12				31.2	4847250			
16	9:25	Bm	0.34	6.8	9.0	0.027	2.12	8.1	1.22	7.5	74	71	12	11	12	12	12	12	12	13	12		X		31.6	4849004				
17	7:45	Bm	0.51	6.9	8.5	0.027	2.25	8.1	1.24	7.7	74	71	12	11	12	11	11	12	12	13	12				30.7	4850501				
18	7:10	Bm	0.34	6.8	8.5	0.023	2.57	8.2	1.85	7.6	74	71	12	12	12	12	12	12	12	13	12			Xp	31.1	4852099				
19	7:45	AH	0.51	6.8	8.0	0.025	2.50	8.1	2.10	7.7	74	71	12	12	12	12	12	12	12	12	12				30.1	4853926				
20	7:25	AH	0.53	6.8	8.5	0.028	2.37	8.1	1.89	7.8	74	71	12	12	12	12	12	12	12	13	12				31.0	4855724				
21	10:00	AK	0.67	6.7	8.0	0.023	2.79	8.2	1.76	7.6	74	71	12	12	12	12	12	12	12	12	12				30.8	4857836				
22	7:35	AK	0.65	6.7	8.5	0.024	2.75	8.1	1.94	7.6	74	71	12	12	12	12	12	12	12	12	12				29.4	4859429				
23	8:10	Bm	0.33	6.8	8.5	0.027	2.71	8.1	2.10	7.6	74	71	12	12	12	12	12	12	12	12	12				30.2	4861215				
24	9:50	Bm	0.34	6.8	8.0	0.025	2.43	8.2	1.95	7.6	74	71	12	12	12	12	12	12	12	13	12	X	X		30.3	4863202				
25	11:45	Bm	0.27	6.8	9.0	0.027	2.15	8.2	1.84	7.6	74	71	12	12	12	12	12	12	12	13	13			Xp	31.5	4865130				
26	8:10	AH	0.31	6.8	9.0	0.020	2.09	8.1	1.67	7.8	73	70	12	12	12	12	12	12	12	13	13				32.4	4866461				
27	8:40	AH	0.31	6.8	8.5	0.025	1.95	8.1	1.66	7.6	74	71	12	12	12	12	12	12	12	12	13				32.4	4868243				
28	13:00	AK	0.34	6.8	8.5	0.027	2.35	8.1	1.37	7.6	73	70	12	12	12	12	12	12	12	12	12				31.0	4870272				
29	9:10	AK	0.41	6.8	8.5	0.022	2.33	8.2	1.79	7.7	75	71	12	12	12	12	12	12	12	12	12				30.7	4871780				
30	10:20	Bm	0.41	6.9	8.5	0.023	2.33	8.3	1.73	7.7	74	71	12	12	12	12	12	12	12	13	12		X	Xp	32.0	4873413				
31	7:10	Bm	0.29	6.9	8.5	0.027	2.35	8.1	1.63	7.8	74	71	12	11	12	12	12	12	12	12	12				30.6	4874834				

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

MONTH 08 YEAR ~~2020~~ 2022

[illegible]