

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	CHL	Flow	Totaliser	
			NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out																
			24 Hr	Initials	deg C	<.1	mg/L	>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi																
1	8:50	AK	0.40	6.9	8.5	0.028	2.34	8.3	1.52	7.8	74	71	12	12	12	12	12	12	12	12	13	12				33.9	4876650	
2	8:30	AH	0.54	6.9	8.0	0.025	2.10	8.3	1.60	7.9	74	71	12	12	12	12	12	12	12	12	13	12				29.3	4878045	
3	8:15	AH	0.33	6.9	8.5	0.023	2.01	8.2	1.66	7.9	74	71	12	12	12	12	12	12	12	12	13	13				29.0	4879696	
4	9:30	AK	0.34	6.8	8.5	0.026	2.25	8.3	1.54	7.7	74	71	12	12	12	12	12	12	12	12	12	12				31.0	4881524	
5	9:50	AK	0.43	6.9	8.5	0.022	2.46	8.3	1.84	7.8	74	71	12	12	12	12	12	12	12	12	12	12				31.2	4883257	
6	9:00	Bm	0.44	7.0	8.5	0.034	1.92	8.3	1.85	7.7	74	71	12	12	12	12	12	12	12	12	13	12	X			30.2	4884806	
7	9:05	Bm	0.49	6.8	9.5	0.044	1.72	8.0	1.72	7.6	74	71	12	12	12	12	12	12	12	13	13	13				32.5	4886394	
8	8:40	Bm	0.96	6.7	9.0	0.023	2.00	8.1	2.30	7.7	74	71	12	12	12	12	12	12	12	12	13	13	Xp			32.6	4887944	
9	10:10	AH	0.28	6.8	8.5	0.024	2.19	8.1	1.58	7.7	74	71	12	12	12	12	12	12	12	12	13	13				31.7	4889592	
10	8:45	AH	0.29	6.7	8.0	0.025	2.15	8.1	1.57	7.6	74	71	12	12	12	14	13	13	13	13	13	13				30.0	4890937	
11	12:45	AK	0.35	6.8	8.0	0.024	2.15	8.2	1.44	7.6	74	71	12	12	12	12	12	12	12	12	13	12				31.3	4892741	
12	9:20	AK	0.48	6.8	8.5	0.023	2.16	8.2	1.74	7.6	74	71	12	12	12	12	12	12	12	12	12	12				31.7	4894017	
13	9:00	Bm	0.34	7.0	7.5	0.025	2.19	8.1	1.68	7.8	74	72	12	12	12	12	12	12	12	12	12	12	X	X		31.6	4895294	
14	9:35	Bm	0.28	7.0	8.5	0.025	2.04	8.3	1.96	7.8	74	70	12	12	12	12	12	12	12	12	12	12				31.5	4896697	
15	9:05	Bm	0.40	6.9	8.5	0.025	1.99	8.1	1.70	7.8	74	71	13	12	12	13	12	12	12	13	13	13		Xp		32.7	4897983	
16	8:30	AH	0.65	7.0	8.5	0.025	1.74	8.2	1.41	7.8	73	70	12	12	12	12	12	12	12	12	14	13				31.7	4899287	
17	8:05	AH	0.26	7.0	8.0	0.025	1.92	8.2	1.47	7.9	74	70	12	12	12	12	12	12	12	12	13	12				32.1	4900655	
18	13:10	AK	0.50	7.0	8.0	0.023	2.01	8.3	1.31	7.7	72	69	12	12	12	12	12	12	12	12	12	12				31.9	4902521	
19	9:00	AK	0.76	7.0	7.0	0.025	1.98	8.4	1.56	7.9	74	71	12	12	12	12	12	12	12	12	13	13				30.3	4903524	
20	8:50	Bm	0.36	7.0	6.0	0.023	1.87	8.4	1.53	7.9	74	71	13	13	13	13	12	13	13	13	13	13	X			31.0	4904674	
21	8:55	Bm	0.26	6.7	8.0	0.024	1.88	8.2	1.51	7.6	74	71	12	12	12	12	12	12	12	12	12	12				31.5	4905948	
22	8:40	Bm	0.26	6.7	7.5	0.026	1.79	8.2	1.43	7.6	74	70	12	12	13	13	12	13	12	12	14	12		Xp		33.2	4907178	
23	8:10	AH	0.33	6.7	7.5	0.025	1.96	8.1	1.39	7.6	74	70	12	12	12	12	12	12	12	12	14	13				32.1	4908398	
24	8:15	AH	0.28	6.7	7.5	0.023	1.77	8.2	1.45	7.7	74	71	12	12	12	12	12	12	12	12	13	12				29.5	4909708	
25	11:00	AK	0.42	6.8	7.0	0.024	1.97	8.2	1.48	7.6	74	70	12	12	12	12	12	12	12	12	12	12				33.9	4911302	
26	9:55	AK	0.39	7.0	7.0	0.023	1.87	8.2	1.50	7.6	74	70	12	12	12	12	12	12	12	12	12	12				32.3	4912595	
27	9:25	Bm	0.20	7.0	6.5	0.024	1.83	8.3	1.51	7.7	74	71	12	12	12	12	12	12	12	12	13	12	X			32.4	4913805	
28	9:40	Bm	0.41	6.8	7.0	0.023	1.97	8.2	1.53	7.6	74	71	12	11	12	12	12	12	12	12	12	12				29.8	4915119	
29	8:55	Bm	0.32	6.8	7.5	0.024	1.84	8.2	1.44	7.6	74	71	12	11	12	12	12	12	12	12	12	12	Xp			30.2	4916314	
30	8:20	AH	0.30	7.0	7.5	0.024	1.89	8.2	1.38	7.7	74	71	12	12	12	12	12	12	12	12	13	13				30.2	4917533	
31																												
BE SURE THAT THE MEMBRANE FEELIENET PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.																												

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point			Comments
			1	2	3	4	5	6	7	8	9	10	Weekly	Temp °F	Clear well Level - Daily											
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP		Gallons		
1	8:50	AG																				7.9	8.5	12600		
2	8:30	AH																						12600		
3	8:15	AH																						12200		
4	9:30	AG																						12700		
5	9:50	AG																						12600		
6	9:00	BM	X		X		X		X		X		X		X		X		X		X			12800		
7	9:05	BM																						12,300		
8	8:40	BM																				7.7	9.0	12600		
9	10:10	AH																						12,400		
10	8:45	AH																						12,000		
11	12:45	AK																						12400		
12	9:20	AK																						12,600		
13	9:00	BM	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X			12,300		
14	9:35	BM																						12,600		
15	9:05	BM																				7.8	8.5	12,700		
16	8:30	AH																						12,500		
17	8:05	AH																						12,200		
18	15:10	AK																						12,600		
19	9:00	AK																						12,700		
20	8:50	BM	X		X		X		X		X		X		X		X		X		X			12,600		
21	8:55	BM																						12,500		
22	8:40	BM																				7.6	7.5	12,500		
23	8:10	AH																						12,500		
24	8:15	AH																						12,600		
25	11:00	AK																						12,800		
26	9:55	AK																						12,400		
27	9:25	BM	X		X		X		X		X		X		X		X		X		X			12,200		
28	9:40	BM																						12,800		
29	8:55	BA																						12,600		
30	8:20	AH																						12,400		
31																										

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete