

DAY	TIME	CERT	Raw			Finished			Distribution		Prefilter		UF 1	UF 2	UF 3	UF 4	UF 5	UF 6	UF 7	UF 8	UF 9	UF 10	CIP	MIT	CHL	Flow	Totaliser				
		OPER	NTU	pH	temp	NTU	CLR	pH	CLR	pH	In	Out	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	TMP	X	P/F	CAL	gpm	Gpd				
	24 Hr	Initials			deg C	<.1	mg/L		>1.2mg/L	>7.3	PSI	PSI	Baseline TMP was 10 psi																		
1	9:30	Bm	0.25	6.7	2.0	0.022	1.05	8.2	0.95	7.4	74	71	14	14	14	14	14	14	14	14	15	14			X _r	32.1	5028657				
2	8:05	AH	0.27	6.8	2.0	0.021	0.97	8.5	0.85	7.7	74	71	14	14	14	14	14	14	14	14	15	14				30.5	5030808				
3	7:50	AH	0.27	6.7	2.0	0.023	1.10	8.4	0.78	7.6	74	71	14	14	14	14	14	14	14	14	14	14				30.4	5033126				
4	7:55	AH	0.27	6.9	2.0	0.021	1.02	8.4	0.88	7.7	74	71	14	14	14	15	14	14	14	15	14	14				29.3	5035461				
5	9:45	Bm	0.28	6.8	2.0	0.021	1.16	8.2	0.84	7.4	74	71	14	14	14	14	14	14	14	15	14				30.4	5038004					
6	8:25	Bm	0.24	6.9	2.0	0.022	1.02	8.4	0.79	7.5	74	71	14	14	14	14	14	14	14	14	14	X	X		30.9	5040207					
7	8:50	Bm	0.33	6.8	1.5	0.022	1.13	8.5	0.96	7.8	74	71	14	14	14	14	14	14	14	15	14				31.8	5042567					
8	9:45	Bm	0.36	6.9	2.0	0.022	1.06	8.3	0.83	8.0	74	71	13	13	13	14	13	13	13	13	14	13			X _r	31.6	5045003				
9	8:00	AH	0.25	6.9	2.0	0.026	1.00	8.5	0.84	8.0	74	71	13	13	13	13	13	13	13	13	14	13				28.0	5047260				
10	8:45	AH	0.23	6.9	2.0	0.023	1.02	8.5	0.76	8.0	74	71	13	13	13	14	13	13	13	13	14	13				30.4	5049771				
11	7:55	AH	0.26	6.9	2.0	0.030	1.00	8.6	0.83	8.1	74	71	13	13	13	14	14	13	13	13	15	14				31.3	5052043				
12	9:45	Bm	0.30	6.9	1.5	0.022	0.98	8.5	0.77	7.7	74	71	13	13	13	14	13	13	13	13	14	13		X		30.8	5054618				
13	8:30	Bm	0.32	7.0	1.5	0.022	1.11	8.5	0.83	7.6	74	71	14	14	14	14	14	13	14	13	14	14			X _{re}	31.6	5056827				
14	9:05	Bm	0.27	7.0	1.5	0.021	1.05	8.4	0.82	7.7	74	71	14	13	13	14	13	13	13	13	14	14				31.3	5059182				
15	8:20	AH	0.34	7.0	1.0	0.025	1.03	8.4	0.85	7.8	74	71	14	14	14	14	14	14	14	14	15	14				30.9	5061375				
16	8:30	AH	0.24	7.0	1.5	0.031	0.94	8.6	0.79	8.1	74	71	14	14	14	15	14	14	14	14	15	14				30.4	5063673				
17	8:00	AH	0.24	6.7	1.5	0.029	1.06	8.4	0.81	7.7	74	71	13	13	13	14	13	13	13	14	14	13				30.2	5065873				
18	8:20	AH	0.31	6.8	1.5	0.025	1.07	8.4	0.83	7.6	74	71	13	13	13	14	13	13	13	14	14	13				30.8	5068258				
19	9:30	Bm	0.24	7.0	1.5	0.022	1.10	8.4	0.82	7.6	74	71	13	13	13	14	13	13	13	13	14	13				30.6	5070775				
20	9:30	Bm	0.25	7.0	1.5	0.028	0.98	8.4	0.72	7.6	74	71	14	14	14	15	14	14	14	14	14	14		X		31.8	5073059				
21	8:35	Bm	0.24	7.0	2.5	0.022	1.08	8.4	0.74	7.6	74	71	13	13	13	14	13	13	13	13	14	14				31.7	5075243				
22	11:55	Bm	0.24	6.9	1.5	0.021	1.00	8.4	0.75	7.5	74	71	14	13	14	13	13	13	13	14	15	14			X _r	31.2	5077773				
23	8:45	AH	0.31	6.8	1.5	0.021	1.08	8.3	0.86	7.6	74	71	14	13	14	14	14	14	14	14	14	14				30.6	5079696				
24	7:55	AH	0.25	7.0	1.5	0.020	1.09	8.6	0.90	7.9	74	71	14	14	14	14	14	14	14	14	15	14				31.7	5081908				
25	8:15	AH	0.27	6.8	2.0	0.021	0.96	8.4	0.89	7.7	74	71	14	14	14	14	14	14	14	14	16	14				31.4	5084310				
26	11:10	Bm	0.32	6.9	1.5	0.021	1.22	8.4	0.88	7.6	74	71	14	14	13	14	14	14	14	14	15	14				30.5	5086944				
27	9:40	Bm	0.26	7.0	1.5	0.020	1.11	8.4	0.84	7.6	74	71	14	14	14	14	14	14	14	14	15	14	X	X		31.3	5089136				
28	9:20	Bm	0.28	6.9	1.5	0.021	1.17	8.1	0.87	7.3	74	71	14	13	13	14	13	13	13	13	14	14				31.9	5091405				
29	11:55	Bm	0.47	6.9	1.5	0.020	1.13	7.8	0.87	7.2	73	70	14	13	13	14	13	13	13	13	14	14			X _r	32.2	5093967				
30	8:40	AH	0.29	6.7	1.5	0.021	1.10	7.7	0.90	7.3	74	71	13	13	13	13	13	13	13	13	14	13				30.7	5095885				
31	8:20	AH	0.24	6.8	2.0	0.021	1.02	8.2	0.85	7.3	73	70	14	14	14	14	14	14	14	14	14	14				31.5	5098172				

BE SURE THAT THE MEMBRANE EFFLUENT PRESSURE (BOTTOM GAUGE) IS ALWAYS OVER 25 PSI AT ALL TIME TO GET PROPER BACKWASHING.

DAY	TIME	CERTIFIED OPERATOR	UF		UF		UF		UF		UF		UF		UF		UF		UF		Distribution Entry Point			Comments
			1	2	3	4	5	6	7	8	9	10	PWT Weekly	Temp °F	Clear Well Level - Daily									
			MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP	MIT	CIP				MIT	CIP	MIT	CIP	MIT	CIP			
1	9:30	Bm																					Gallons	
2	8:05	AH																			7.4	2.0	12,500	
3	7:50	AH																					12,100	
4	7:55	AH																					12,000	
5	9:45	Bm																					12,200	
6	8:25	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X			12,600	
7	8:50	Bm																					12,200	
8	9:45	Bm																					12,100	
9	8:00	AH																			7.9	2.0	12,400	
10	8:45	AH																					12,100	
11	7:55	AH																					12,100	
12	9:45	Bm	X		X		X		X		X		X		X		X		X				12,400	
13	8:30	Bm																					12,400	
14	9:05	Bm																					12,400	
15	8:20	AH																			7.7	1.5	12,200	
16	8:20	AH																					12,400	
17	8:00	AH																					12,300	
18	8:20	AH																					12,300	
19	9:50	Bm																					12,200	
20	9:30	Bm	X		X		X		X		X		X		X		X		X				12,400	
21	8:35	Bm																					12,400	
22	11:55	Bm																					12,200	
23	8:45	AH																			7.5	1.5	12,500	
24	7:55	AH																					12,200	
25	8:15	AH																					12,000	
26	11:10	Bm																					12,100	
27	9:45	Bm	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X			12,000	
28	9:20	Bm																					12,500	
29	8:55	Bm																			7.3	1.5	12,600	
30	8:40	AH																					12,500	
31	8:20	AH																					12,300	
																							12,200	

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete

Note: MIT - Pass (P) or Fail (F)
Note: CIP - X for complete