

10/5/21	MIT X10	Bm
10/7/21	NEW CLEARWELL TANKS INTO BUILDING	Bm, AG, AH
10/10/21	NEW SOUTH SIDE ROOF	Bm/AG, AH
10/12/21	MIT X10	Bm
10/19/21	CIP X10 / MIT X10	Bm
10/19/21	CLEANED CHORIMETER / REPLACED CHEMS	Bm
10/26/21	MIT X10	Bm
11/2/21	MIT X10	Bm
11/2/21	6FI FOR SEWER HEATERS INSTALLED	Bm
11/9/21	CIP X10 / MIT X10	Bm
11/16/21	MIT X10	Bm
11/18/21	NEW TANKS ONLINE w/ CONTROL VALVE	Bm/AG
11/23/21	MIT X10	Bm
11/23/21	RAN PUMP #2 24 HOURS	Bm
11/26/21	PREFILTER MAINT / STOPPED LEAKS	Bm/AG
11/30/21	CIP X10 / MIT X10	Bm
11/30/21	GREASED HIGHLINE PUMP	Bm
12/7/21	MIT X10	AG
12/11/21	HIGHLINE BLEEDER / BYPASS PUMPED UP	Bm/AG
12/14/21	MIT X10	Bm
12/16/21	TURNED UP BLEEDERS - NEWTON, MURKIS, KUCH $\rightarrow$ 2.0 OPERATOR $\rightarrow$ 1.0	Bm
12/21/21	REPLACED AIR RELIEF VALVE #3	Bm
12/21/21	CIP X10 / MIT X10	Bm
12/26/21	Calibrate turbidimeters	AG
12/29/21	MIT X10	Bm
1/4/22	MIT X10	Bm
1/11/22	CIP X10 / MIT X10	Bm
1/17/22	calibrate Turbidity meters	AG
1/18/22	MIT X10	Bm
1/25/22	MIT X10	Bm